

Electrical Systems, Commercial Building Design

AREN 4570, Spring 2013

5/2/2013

Janay Griego, Matthew Kincaid, Travis Marcilla



Executive Summary

The following 21,000sqft office building utilizes a radial distribution system which consists of a 480Y/277V lighting panel, a 208Y/120V power panel, and a 480Y/277V motor control center. 1”C-4#2THW (cu) conductors protected by a 100 A breaker, supply two types of lights and occupancy sensors. There are two circuits per floor with a centrally located panel board in the utility room on the second floor. The down lights have a battery option in order to double as egress lighting in a power outage. Occupancy sensors are used to help save energy. The power panel is fed by a 1”C-4#8 THW (cu) through a 100A breaker and supplies 36 individual receptacle branches. Emergency exit signs with a backup battery are hard wired into the same circuits as nearby outlets. Care has been taken to leave plenty of room for large and potentially continuous loads that may be a result of multiple computers and other office gadgets. Each floor has a plug wired for a refrigerator and circuit available for a small appliance load.

The motor control center is fed by 2”C-3#3/0 THW (cu) protected by a 300 A breaker. There are 13 individual motor loads. The control center is located in the mechanical and electrical room on the first floor and next to the 9’6” X 4’6” X 7’6” unit substation. The 225kV transformer that feeds the power panel is directly below the power panels in the same room. The chiller is the largest motor at 30hp and is selected from the line of Carrier products.

The second floor of the building is home to the power panels but the chiller, boiler, and the hot and chilled water pumps. These feed the AHU that is located directly above on the third floor. The goals project goals established by the design team include safety, flexibility, minimal energy demand, low voltage drops, and minimal equipment sizing to save money.

Table of Contents

Executive Summary.....2

Table of Contents.....3

NEC Compliance.....4

Lighting Panel.....6

Power Panel.....8

Emergency Loads.....10

Motor Control.....11

Motor Branch Circuits.....14

Unit Substation.....17

Voltage Drop.....19

Short Circuit.....21

Wire Sizes.....23

References.....25

Appendix A: Drawings.....26

Appendix B: Cut Sheets.....44

NEC Code Compliance Summary

| Table 1: Reference to Electrical Systems for Buildings. | |
|--|--|
| Textbook Table | Description |
| 14.1 | Horsepower ratings of low-voltage starters |
| 14.3 | Space requirements for motor control centers |
| 8.2 | Frame sizes and typical ratings for low-voltage power circuit breakers |
| Fig 15.8 | Modular stacking arrangements for low-voltage circuit breaker switchboards |
| 13.4 | Standard Ratings of Three-Pole Motor Circuit Switches |
| 15.1 | Ratings and Typical Cubicle Dimensions for Dry-Type Transformers Used with Unit Substations. |
| 7.1 | Ratings and Clearing Time Limits for Low-Voltage Fuses up to 600 Amperes |

| Table 2: Tables Referenced in NEC | | |
|--|--|-----------------------------|
| Table | Description | Text Book Equivalent |
| 430.52 | Maximum Rating or Setting of Motor Branch-Circuit and Ground-Fault Protective Devices. | 13.3 |
| 430.72 | Maximum Rating of Overcurrent Protective Device in Amperes | |
| 430.250 | Full-Load Current in Amperes, Direct-Current Motors | 13.2 |
| 220.44 | Demand factors for Non-Dwelling Receptacle Loads | 12.3 |
| 220.122 | Minimum Size Equipment Grounding Conductors for Grounding Raceway and Equipment. | 10.2 |
| 310.15 (B) (16) | Allowable Ampacities of Insulated Conductors | 11.1 |
| Annex C | Maximum Number of Conductors in Trade Size of Conduit or Tubing. | 11.6 |
| 250.66 | Grounding Electrode Conductor for Alternating Current Systems | 10.1 |
| Chap 9, T9 | Alternating-Current Resistance and Reactance for 600-Volt Cables. | 16.1 |

| Table 3: Articles Referenced in NEC | |
|--|---|
| Article | Summary |
| 430.6 | Describes how to size the conductors of the equipment |
| 430.32 | Any continuous motor that is more than 1hp shall have overcurrent protection. |
| 430.37 | All 3-Phase motors must be provided with overload units. |
| 430.39 | Motor controllers need to be installed that is capable of interrupting a stalled rotor current of the motor. |
| 450.42 | The vault that holds the transformer shall provide 3 hour fire resistance. |
| 450.43 | doorways shall also be fire protected |
| 430.40 | If there is a maximum short circuit then there is a maximum limit on the fuse or circuit breaker. |
| 430.52 | The motor branch-circuit short-circuits and ground-fault protective device shall be capable of carrying the starting current in the motor, and much more. |
| 430.72 | Describes overcurrent protection for motor control circuits. |
| 220.14 (I) | Receptacle demand loads. |
| 220.18 (A) | Continuous motors are 125% DF. |
| 250.122 | Size equipment grounding |
| 110.26 | Defines Space Requirements around Unit Substation. |
| 700.12 (F) | Lights with rechargeable batteries are required |

Lighting Types

Throughout the building, three different types of luminaires will be used. Lighting for the exterior of the building will be provided by exterior wall luminaire hood downlights. These luminaires are only located on the outer perimeter. The layout of this specific lighting can be seen on CAD Sheet E3.1. As for the main lighting for all office spaces in the building, troffers are used on each level. Spaces where troffers are located include utility rooms, open office areas, the cafeteria, and storage rooms. For conference rooms and private offices, a more ambient lighting fixture was chosen. For the ambient lighting, commercial downlighting is implemented. For energy savings, occupancy sensors are also installed. These sensors can be set to a specified time and will automatically turn off the lights if there is no movement in the room/space.

| Luminaire Description | | | | | | |
|------------------------|------------------------------------|--------------|---------|---------|----------|--|
| Fixture | Model # | Manufacturer | Wattage | Voltage | Quantity | Notes |
| Exterior Wall Lighting | 697-WP-MH/1/100-277V-BK-C | Shaper | 100 | 277 | 10 | Exterior lighting near entrances |
| Troffers | 2-VRM-S-2-54T5-PA3-75-277-LEOC8-GL | ISO | 122 | 277 | 96 | All troffers per floor are wired together and connected to a single fuse on the 2 nd floor. |
| Down Lights | PD8H142-E-82H-1G-C-HB128APK | Halo | 45 | 277 | 182 | Used for private offices/conference rooms and hallways. |
| Occupancy Sensors | VAC-DT-2000-R | Greengate | 0.75 | 277 | 32 | Purpose is to help improve energy consumption. |

Table 4: Shows the purpose and use for each luminaire in various spaces of the commercial building.

Lighting Loads

| Fixture | # of Fixtures | Watts per Fixture | PF | P _r per Fixture, VA | Connected Load, kVA | Demand Load, kVA |
|------------------------|---------------|-------------------|------|--------------------------------|---------------------|------------------|
| Exterior Wall Lighting | 10 | 100 | 0.98 | 102.04 | 1.02 | 1.28 |
| Troffer | 96 | 122 | 0.98 | 124.49 | 11.95 | 14.94 |
| Down Light | 182 | 45 | 0.98 | 45.92 | 8.36 | 10.45 |
| Occupancy Sensor | 32 | 0.75 | 1 | 0.75 | 0.02 | 0.03 |
| TOTAL: | | | | | 21.35 | 26.69 |

Table 5: The amount of each fixture was totaled. The connected loads and demand loads are calculated and displayed. In a commercial building, a demand factor of 1.25 should be applied to all lights.

Equations/Sample Calculations using Exterior Wall Lighting:

$$\text{Total Power per Fixture, } P_T/\text{fixture} = \frac{\left(\frac{W}{\text{Fixture}}\right)}{PF} = \frac{100}{0.98} = \mathbf{102.04 VA}$$

$$\text{Connected Load} = \frac{(\# \text{ of Fixtures}) \left(\frac{P_T}{\text{Fixture}}\right)}{1000 VA} * kVA = \frac{(10 \text{ Fixture})(102.04 VA)}{1000 VA} = \mathbf{1.02 kVA}$$

$$\text{Demand Load} = 1.25 * \text{Connected Load} = 1.25 * 1.02 kVA = \mathbf{1.28 kVA}$$

Lighting Panel: Lighting Branch Circuits

All lighting used is fluorescent lighting which requires a smaller amount of power. Because of this, a total of six branch circuits are needed. The load for branches L1-L6 are shown below. The total load should add up to the already calculated connected load and demand load shown above in Table 5.

| Branch Circuit | Troffers | Exterior Lights | Down Lights | Occupancy Sensor | Connected Load, kVA | Demand Load, kVA | Current, Amps |
|----------------|----------|-----------------|-------------|------------------|---------------------|------------------|---------------|
| L1 | 28 | 10 | 0 | 4 | 4.51 | 5.64 | 20.35 |
| L2 | 0 | 0 | 58 | 6 | 2.67 | 3.33 | 12.04 |
| L3 | 34 | 0 | 0 | 4 | 4.24 | 5.29 | 19.11 |
| L4 | 0 | 0 | 62 | 7 | 2.85 | 3.57 | 12.87 |
| L5 | 34 | 0 | 0 | 4 | 4.24 | 5.29 | 19.11 |
| L6 | 0 | 0 | 62 | 7 | 2.85 | 3.57 | 12.87 |
| | | | | TOTAL: | 21.35 | 26.69 | 96.36 |

Table 6: Shows the load associated with each branch circuit in the lighting panel based on the luminaire ratings for each fixture.

| POWER PANEL LOADS | | | | |
|-------------------|--------------|--------------|---------------------|---------------|
| Circuit | Receptacles* | Exit Signs** | Connected Load, kVA | Current, Amps |
| 1 | 8 | 0 | 1.44 | 12 |
| 2 | 8 | 0 | 1.44 | 12 |
| 3 | 7 | 0 | 1.26 | 10.5 |
| 4 | 7 | 0 | 1.26 | 10.5 |
| 5 | 10 | 0 | 1.8 | 15 |
| 6 | 7 | 2 | 1.269 | 10.575 |
| 7 | 4 | 3 | 0.7335 | 6.1125 |
| 8 | 8 | 0 | 1.44 | 12 |
| 9 | 1 | 0 | 0.18 | 1.5 |
| 10 | 2 | 0 | 0.36 | 3 |
| 11 | 10 | 0 | 1.8 | 15 |
| 12 | 8 | 0 | 1.44 | 12 |
| 13 | 8 | 0 | 1.44 | 12 |
| 14 | 8 | 0 | 1.44 | 12 |
| 15 | 8 | 0 | 1.44 | 12 |
| 16 | 9 | 0 | 1.62 | 13.5 |
| 17 | 6 | 1 | 1.0845 | 9.0375 |
| 18 | 9 | 0 | 1.62 | 13.5 |
| 19 | 10 | 0 | 1.8 | 15 |
| 20 | 9 | 2 | 1.629 | 13.575 |
| 21 | 1 | 0 | 0.18 | 1.5 |
| 22 | 2 | 0 | 0.36 | 3 |
| 23 | 8 | 0 | 1.44 | 12 |
| 24 | 6 | 1 | 1.0845 | 9.0375 |
| 25 | 8 | 2 | 1.449 | 12.075 |
| 26 | 8 | 0 | 1.44 | 12 |
| 27 | 8 | 0 | 1.44 | 12 |
| 28 | 8 | 0 | 1.44 | 12 |
| 29 | 9 | 0 | 1.62 | 13.5 |
| 30 | 9 | 0 | 1.62 | 13.5 |
| 31 | 10 | 0 | 1.8 | 15 |
| 32 | 9 | 2 | 1.629 | 13.575 |
| 33 | 1 | 0 | 0.18 | 1.5 |
| 34 | 2 | 0 | 0.36 | 3 |
| 35 | 8 | 0 | 1.44 | 12 |
| 36 | 8 | 2 | 1.449 | 12.075 |
| | | SUM: | 45.43 | 378.56 |

Table 7: Displays the load associated with each circuit in the power panel. The circuiting is laid out from the one-line diagrams provided.

Equations/Sample Calculations using Circuit 7:

*According to NEC Article 220.14(I), receptacle loads should be rated at 180 VA per receptacle.

**Referring to the cut sheets in the Appendix, exit signs are rated at 4.5 VA.

$$\begin{aligned} \text{Connected Load (Circuit 7)} &= \frac{(\# \text{ of receptacles})(180 \text{ VA}) + (\# \text{ of exit signs})(4.5 \text{ VA})}{1000 \text{ VA}} * \text{kVA} \\ &= \frac{(4 \text{ receptacles})(180 \text{ VA}) + (3 \text{ exit signs})(4.5 \text{ VA})}{1000 \text{ VA}} = \mathbf{0.7335 \text{ kVA}} \end{aligned}$$

Demand Load:

According to NEC Article 220.44, the calculated demand load for receptacle loads is found through the following equation:

$$DL = 100\% * 10 \text{ kVA} + 50\%(\text{remainder} - 10 \text{ kVA})$$

In this case, the connected load was calculated to be 45.43 kVA as shown in Table 7. Therefore:

$$DL = (100\% * 10 \text{ kVA} + 50\%(45.43 \text{ kVA} - 10 \text{ kVA})) = \mathbf{27.72 \text{ kVA}}$$

Emergency Load Description

In case of emergency, load requirements include egress lighting and exit signs. The egress lighting luminaires used are the same commercial Halo downlights used throughout the building as described in the lighting loads section. These luminaires have the option to change the ballast from a regular downlight to a downlight with a dual-tap emergency battery ballast with a remote test switch plate. This means that these luminaires are used daily for general lighting and are powered through the lighting panel and when an emergency occurs, the battery back-up will then be the source of power.

In addition to egress lighting, exit signs will also be needed for safety purposes. The exit signs chosen to be installed in the building will be energy efficient, long life LEDs. This specific type was chosen for its low operating costs and zero maintenance requirements.

| Emergency Load Description | | | | | | |
|----------------------------|-----------------------------|--------------|---------|---------|----------|---|
| Fixture | Model # | Manufacturer | Wattage | Voltage | Quantity | Notes |
| Emergency Down Lights | PD8H142-E-82H-1G-C-HB128APK | Halo | 45 | 277 | 182 | Includes battery backup ballast. |
| Exit Signs | ECHX-2-ST-A-WH | Sure-Lights | 4.5 | 277 | 15 | Ordered with arrows facing in the proper direction. |

Table 8: Emergency loads are shown. Refer to the cut sheets in the Appendix for more information.

As mentioned above, the emergency downlights are a part of the lighting panel with battery back-up. The exit signs are connected to the power panel along with receptacle loads. See CAD sheets E4.1-E4.3 for exit sign layout and sheets E3.1-E3.3 for emergency downlighting layout.

Exit signs will have a very low load to the LED type exit sign. For load contribution to the power panel, see Table 7 in the Power Panel Design section.

According to NEC article 700.12(F), lights with rechargeable batteries are required. This complies with the ballast and luminaire type specified.

| Motor # | Motor | HP | # of Motors | PF | Efficiency | Control | Total Power, P _T | Real Power, P _R | Reactive Power, P _X | NEMA Starter* | SF/Motor ** | SF Total |
|---------|----------------------------|----|-------------|------|------------|--------------|-----------------------------|----------------------------|--------------------------------|---------------|-------------|-----------|
| M1 | AHU Supply Fan | 25 | 1 | 0.9 | 0.92 | RVNR | 22.52 | 20.27 | 9.82 | 2 | 5 | 5 |
| M2 | AHU Return Fan | 15 | 1 | 0.9 | 0.92 | RVNR | 13.51 | 12.16 | 5.89 | 2 | 5 | 5 |
| M3 | CHW Pump | 20 | 1 | 0.9 | 0.92 | RVNR | 18.02 | 16.22 | 7.85 | 2 | 5 | 5 |
| M4 | Elevator | 20 | 1 | 0.9 | 0.9 | RVR | 18.42 | 16.58 | 8.03 | 2 | 5 | 5 |
| M5 | AHU Exhaust Fan | 10 | 1 | 0.9 | 0.92 | RVNR | 9.01 | 8.11 | 3.93 | 1 | 5 | 5 |
| M6 | HW Pump | 10 | 1 | 0.9 | 0.92 | RVNR | 9.01 | 8.11 | 3.93 | 1 | 5 | 5 |
| M7-M12 | Exhaust Fans (6 Restrooms) | 1 | 6 | 0.85 | 0.95 | FVNR | 0.92 | 0.79 | 0.49 | 00 | 1 | 6 |
| M13 | Chiller | 30 | 1 | 0.9 | 0.9 | RVNR | 27.63 | 24.87 | 12.04 | 3 | 8 | 8 |
| | | | | | | Total | 119.05 | 107.1 | 51.98 | | | 44 |

Table 9: A summary of all motor loads present in the commercial building.

*NEMA Starter based on three-phase, 460 V motor loads

*SF/motor based on fusible switch type

Equations/Sample Calculations using AHU Supply Fan, Motor 1:

$$\text{Real Power, } P_R = \frac{P_{mech}}{\eta} = \frac{25 \text{ HP}}{0.92} * \frac{0.746 \text{ kW}}{\text{HP}} = \mathbf{20.27 \text{ kW}}$$

$$\text{Total Power, } P_T = \frac{P_R}{PF} = \frac{20.27 \text{ kW}}{0.9} = \mathbf{22.52 \text{ kVA}}$$

$$\text{Reactive Power, } P_X = \sqrt{P_T^2 - P_R^2} = \sqrt{22.52^2 - 20.27^2} = \mathbf{9.82 \text{ kvar}}$$

Demand Load:

Connected Load = 119.05 kVA from Table 9

To calculate the demand load, a demand factor of 1.25 must be applied to the power of the largest motor. In this case, the largest motor present is the chiller at 27.87 kVA.

$$DL = 1.25 * P_{T,largest} + \sum P_{T,remainder} = 1.25 * 27.87 \text{ kVA} + 91.42 \text{ kVA} = \mathbf{126.26 \text{ kVA}}$$

Number of Modules:

Total Space Factor

- 44 SF for all motors
- 1 SF for main feeder

| |
|---------------------------|
| TOTAL SF = 44 + 1 = 45 SF |
|---------------------------|

12 Space Factors are allowed in one module \longrightarrow 45 SF/12 = 3.75 \longrightarrow **4 modules** are needed to house all motors

Motor Control Center Horizontal and Vertical Bus Sizes:

Standard Horizontal Bus Sizes (continuous current rating)-

[600 A, 1000 A, 1200 A, 1600 A, 2000 A]

| Horizontal Bus Size | | | | |
|----------------------------|-------|----------|-----------------------------|--------------|
| Motor | HP | I (Amps) | # Motors | DL |
| AHU Supply Fan | 25 HP | 34 | 1 | 34 |
| AHU Return Fan | 15 HP | 21 | 1 | 21 |
| CHW Pump | 20 HP | 27 | 1 | 27 |
| Elevator | 20 HP | 27 | 1 | 27 |
| AHU Exhaust Fan | 10 HP | 14 | 1 | 14 |
| HW Pump | 10 HP | 14 | 1 | 14 |
| Exhaust Fans (6 Restrooms) | 1 HP | 1.8 | 6 | 10.8 |
| Chiller | 30 HP | 40 | 1 | 40 |
| | | | SUM: | 187.8 |
| | | | Horizontal Bus Size: | 600 A |

Table 10: Summary of calculations used to find the horizontal bus size of the motor control center.

Standard Vertical Bus Sizes-
 [300 A, 450 A, 600 A]

Sample Calculation using Module 1:

In order to find the standard vertical bus size, the demand load must be calculated.

Module 1 contains the AHU Supply Fan and AHU Return Fan only. A demand factor of 1.25 should be applied to the largest motor within the module.

$$DL \text{ for Module 1} = 1.25 * I_{L, \text{AHU Supply Fan}} + I_{L, \text{AHU Return Fan}} = 1.25 * 34 \text{ A} + 21 \text{ A} = \mathbf{63.5 \text{ A}}$$


Therefore, a 300 A vertical bus size is selected for Module 1.

| Vertical Bus Size | |
|-------------------|--------------|
| <i>Module 1</i> | |
| DL (A) | 63.5 |
| VB 1 Size | 300 A |
| <i>Module 2</i> | |
| DL (A) | 64.35 |
| VB 2 Size | 300 A |
| <i>Module 3</i> | |
| DL (A) | 57.2 |
| VB 2 Size | 300 A |
| <i>Module 4</i> | |
| DL (A) | 31.5 |
| VB 2 Size | 300 A |

Table 11: Summary of vertical bus sizes for all four modules in the motor control center

Horizontal and Vertical Bus Size Schematic

*For an overall layout of the MCC, see CAD Sheet E8.



Motor 1: AHU Supply Fan, RVNR

25 HP, 460 V, 3 phase, SF = 10%, Nontime-Delay Fuse Protection

| STEP 1: LOAD | | |
|--------------|------|--------------|
| $I_L =$ | 34 A | NEC(430.250) |

| STEP 2: PROTECTION DEVICE | | |
|---------------------------|------|-------------|
| DF = | 250% | NEC(430.52) |
| $I_{fuse} = 2.5 * I_L =$ | 85 | |
| Use 90 A Fuse | | T7.1 |

| STEP 3: CONDUCTOR/CONDUIT | | |
|---------------------------|--------|--------------|
| $I_{cond} =$ | 42.5 A | continuous |
| #8 THW (Cu) | | NEC(310.15B) |
| 3/4" C - 3#8 THW | | NEC(AnnexC) |

| STEP 4: SWITCHES | | |
|----------------------|-------|-------|
| <i>Nontime-Delay</i> | | |
| Fused Switch | 100 A | T13.4 |
| Unfused Switch | 60 A | T13.4 |

| STEP 5: OVERLOAD PROTECTION | | |
|-----------------------------|--------|--|
| $I_{FLC} =$ | 34 A | |
| $I_{OC} =$ | 39.1 A | |

| STEP 6 | |
|------------|------|
| Controller | RVNR |

Motor 2: AHU Return Fan, RVNR

15 HP, 460 V, 3 phase, SF =10%, Nontime-Delay Fuse Protection

| STEP 1: LOAD | | |
|--------------|------|--------------|
| $I_L =$ | 21 A | NEC(430.250) |

| STEP 2: PROTECTION DEVICE | | |
|---------------------------|------|-------------|
| DF = | 250% | NEC(430.52) |
| $I_{fuse} = 2.5 * I_L =$ | 52.5 | |
| Use 60 A Fuse | | T7.1 |

| STEP 3: CONDUCTOR/CONDUIT | | |
|---------------------------|---------|--------------|
| $I_{cond} =$ | 26.25 A | continuous |
| #12 THW (Cu) | | NEC(310.15B) |
| 1/2" C - 3#12 THW | | NEC(AnnexC) |

| STEP 4: SWITCHES | | |
|----------------------|------|-------|
| <i>Nontime-Delay</i> | | |
| Fused Switch | 60 A | T13.4 |
| Unfused Switch | 30 A | T13.4 |

| STEP 5: OVERLOAD PROTECTION | | |
|-----------------------------|---------|--|
| $I_{FLC} =$ | 21 A | |
| $I_{OC} =$ | 24.15 A | |

| STEP 6 | |
|------------|------|
| Controller | RVNR |

Motor 3: CHW Pump, RVNR

20 HP, 460 V, 3 phase, SF =10%, Nontime-Delay Fuse Protection

| STEP 1: LOAD | | |
|--------------|------|--------------|
| $I_L =$ | 27 A | NEC(430.250) |

| STEP 2: PROTECTION DEVICE | | |
|---------------------------|------|-------------|
| DF = | 250% | NEC(430.52) |
| $I_{fuse} = 2.5 * I_L =$ | 67.5 | |
| Use 70 A Fuse | | T7.1 |

| STEP 3: CONDUCTOR/CONDUIT | | |
|---------------------------|---------|--------------|
| $I_{cond} =$ | 33.75 A | continuous |
| #10 THW (Cu) | | NEC(310.15B) |
| 1/2" C - 3#10 THW | | NEC(AnnexC) |

| STEP 4: SWITCHES | | |
|----------------------|-------|-------|
| <i>Nontime-Delay</i> | | |
| Fused Switch | 100 A | T13.4 |
| Unfused Switch | 60 A | T13.4 |

| STEP 5: OVERLOAD PROTECTION | | |
|-----------------------------|---------|--|
| $I_{FLC} =$ | 27 A | |
| $I_{OC} =$ | 31.05 A | |

| STEP 6 | |
|------------|------|
| Controller | RVNR |

Motor 4: Elevator, RVR

20 HP, 460 V, 3 phase, SF =10%, Nontime-Delay Fuse Protection

| STEP 1: LOAD | | |
|--------------|------|--------------|
| $I_L =$ | 27 A | NEC(430.250) |

| STEP 2: PROTECTION DEVICE | | |
|---------------------------|------|-------------|
| DF = | 250% | NEC(430.52) |
| $I_{fuse} = 2.5 * I_L =$ | 67.5 | |
| Use 70 A Fuse | | T7.1 |

| STEP 3: CONDUCTOR/CONDUIT | | |
|---------------------------|---------|--------------|
| $I_{cond} =$ | 33.75 A | continuous |
| #10 THW (Cu) | | NEC(310.15B) |
| 1/2" C - 3#10 THW | | NEC(AnnexC) |

| STEP 4: SWITCHES | | |
|----------------------|-------|-------|
| <i>Nontime-Delay</i> | | |
| Fused Switch | 100 A | T13.4 |
| Unfused Switch | 60 A | T13.4 |

| STEP 5: OVERLOAD PROTECTION | | |
|-----------------------------|---------|--|
| $I_{FLC} =$ | 27 A | |
| $I_{OC} =$ | 31.05 A | |

| STEP 6 | |
|------------|-----|
| Controller | RVR |

| Motor 5: AHU Exhaust Fan, RVNR | | | Motor 6: HW Pump, RVNR | | |
|--|--------------------------|--------------|--|--------------------------|--------------|
| 10 HP, 460 V, 3 phase, SF = 10%, Nontime-Delay Fuse Protection | | | 10 HP, 460 V, 3 phase, SF = 10%, Nontime-Delay Fuse Protection | | |
| STEP 1: LOAD | | | STEP 1: LOAD | | |
| $I_L =$ | 14 A | NEC(430.250) | $I_L =$ | 14 A | NEC(430.250) |
| STEP 2: PROTECTION DEVICE | | | STEP 2: PROTECTION DEVICE | | |
| DF = | 250% | NEC(430.52) | DF = | 250% | NEC(430.52) |
| $I_{fuse} = 2.5 * I_L =$ | 35 | | $I_{fuse} = 2.5 * I_L =$ | 35 | |
| | Use 35 A Fuse | T7.1 | | Use 35 A Fuse | T7.1 |
| STEP 3: CONDUCTOR/CONDUIT | | | STEP 3: CONDUCTOR/CONDUIT | | |
| $I_{cond} =$ | 17.5 A | continuous | $I_{cond} =$ | 17.5 A | continuous |
| | #12 THW (Cu)* | NEC(310.15B) | | #12 THW (Cu)* | NEC(310.15B) |
| | 1/2" C - 3#12 THW | NEC(AnnexC) | | 1/2" C - 3#12 THW | NEC(AnnexC) |
| STEP 4: SWITCHES | | | STEP 4: SWITCHES | | |
| <i>Nontime-Delay</i> | | | <i>Nontime-Delay</i> | | |
| Fused Switch | 60 A | T13.4 | Fused Switch | 60 A | T13.4 |
| Unfused Switch | 30 A | T13.4 | Unfused Switch | 30 A | T13.4 |
| STEP 5: OVERLOAD PROTECTION | | | STEP 5: OVERLOAD PROTECTION | | |
| $I_{FLC} =$ | 14 A | | $I_{FLC} =$ | 14 A | |
| $I_{OC} =$ | 16.1 A | | $I_{OC} =$ | 16.1 A | |
| STEP 6 | | | STEP 6 | | |
| Controller | RVNR | | Controller | RVNR | |

| Motors 7-12: Exhaust Fans, FVNR | | | Motor 13: Chiller, RVNR | | |
|---|--------------------------|--------------|--|-------------------------|--------------|
| 1 HP, 460 V, 3 phase, SF = 10%, Nontime-Delay Fuse Protection | | | 30 HP, 460 V, 3 phase, SF = 10%, Nontime-Delay Fuse Protection | | |
| STEP 1: LOAD | | | STEP 1: LOAD | | |
| $I_L =$ | 1.8 A | NEC(430.250) | $I_L =$ | 40 A | NEC(430.250) |
| STEP 2: PROTECTION DEVICE | | | STEP 2: PROTECTION DEVICE | | |
| DF = | 300% | NEC(430.52) | DF = | 250% | NEC(430.52) |
| $I_{fuse} = 3 * I_L =$ | 5.4 | | $I_{fuse} = 2.5 * I_L =$ | 100 | |
| | Use 15 A Fuse | T7.1 | | Use 100 A Fuse | T7.1 |
| STEP 3: CONDUCTOR/CONDUIT | | | STEP 3: CONDUCTOR/CONDUIT | | |
| $I_{cond} =$ | 2.25 A | continuous | $I_{cond} =$ | 50 A | continuous |
| | #12 THW (Cu)* | NEC(310.15B) | | #8 THW (Cu) | NEC(310.15B) |
| | 1/2" C - 3#12 THW | NEC(AnnexC) | | 3/4" C - 3#8 THW | NEC(AnnexC) |
| STEP 4: SWITCHES | | | STEP 4: SWITCHES | | |
| <i>Nontime-Delay</i> | | | <i>Nontime-Delay</i> | | |
| Fused Switch | 30 A | T13.4 | Fused Switch | 200 A | T13.4 |
| Unfused Switch | 15 A | T13.4 | Unfused Switch | 60 A | T13.4 |
| STEP 5: OVERLOAD PROTECTION | | | STEP 5: OVERLOAD PROTECTION | | |
| $I_{FLC} =$ | 1.8 A | | $I_{FLC} =$ | 40 A | |
| $I_{OC} =$ | 2.07 A | | $I_{OC} =$ | 46 A | |
| STEP 6 | | | STEP 6 | | |
| Controller | FVNR | | Controller | RVNR | |

*Upsized from a #14 THW (Cu): #12 THW (Cu) is the minimum required size for a motor branch circuit.

Sizing the Main MCC Feeder

| CONDUCTOR/CONDUIT | | | |
|-------------------|--|---|--------------|
| $I_{cond} =$ | $1.25 * I_{largest, M} + \text{Sum } I_{L, remainder}$ | | |
| | 197.8 | A | |
| | #3/0 THW (Cu) | | NEC(310.15B) |
| | 2" C - 3#3/0 THW | | NEC(AnnexC) |

| PROTECTION DEVICE: Circuit Breaker | | | |
|------------------------------------|--|---|-------------|
| DF = | 250% | | NEC(430.52) |
| $I_p =$ | $DF * I_{largest, M} + \text{Sum}(I_{L, remainder})$ | | |
| | 247.8 | A | |
| | Use 300 A CB | | T8.2 |

| Demand Load Summary | | |
|---------------------|-------------------|--------------------------------|
| Load | Demand Load, kVA | Calculations Found in Section: |
| Lighting | 26.69 | Lighting Panel Design |
| Receptacles | 27.72 | Power Panel Design |
| Motors | 126.26 | Motor Control Center Design |
| SUM: | 180.67 kVA | |

Table 12: Collected demand load summary.

To allow for flexibility in the design, the unit substation transformer is sized to be approximately 20% larger than the demand load requires.

Sizing the Transformer:

| Power Rating (kVA) | Height (in) | Width (in) | Depth (in) | Weight (lbs) | Average Impedance (%Z) | Average X/R Ratio |
|--------------------|-------------|------------|------------|--------------|------------------------|-------------------|
| 15.0 | 23.00 | 22.25 | 15.00 | 230 | 3.6 | 1.94 |
| 30.0 | 23.00 | 22.25 | 15.00 | 285 | 6.4 | 0.92 |
| 45.0 | 26.00 | 24.00 | 15.00 | 369 | 6.6 | 1.13 |
| 75.0 | 30.00 | 30.00 | 20.00 | 590 | 5.7 | 1.38 |
| 112.5 | 37.00 | 30.00 | 20.00 | 690 | 6.1 | 1.51 |
| 150.0 | 42.00 | 36.00 | 24.00 | 1050 | 5.5 | 1.53 |
| 225.0 | 42.00 | 36.00 | 24.00 | 1350 | 6.6 | 2.00 |
| 300.0 | 48.00 | 48.00 | 29.50 | 2000 | 3.6 | 1.81 |
| 500.0 | 58.00 | 48.00 | 29.50 | 2700 | 5.0 | 2.89 |
| 750.0 | 90.00 | 72.00 | 54.00 | 5200 | 5.0 | 1.98 |
| 1000.0 | 90.00 | 72.00 | 54.00 | 6000 | 5.8 | 2.38 |

Table 13: Typical Ratings of Three-Phase General Purpose Transformers. See reference 1 for source citation.

From Table X, a transformer that is approximately 20% larger than a 180.67 kVA demand load is a **225 kVA** transformer.

| Unit Substation Dimensions | |
|-----------------------------------|---|
| Unit Substation Element | Sizing |
| Primary Switchgear Current | $I_{L,P} = \frac{P_T}{\sqrt{3}(E_{L,P})} = \frac{180.67 \text{ kVA}}{\sqrt{3}(13.8 \text{ kV})} = 7.56 \text{ A}$ Use low current: 600 A Size: W = 36" |
| Transformer | Use 15 kV, 225 kVA Size: T15.5 – H = 90", W = 42", D = 54" |
| Main Secondary Current | $I_{L,S} = \frac{P_T}{\sqrt{3}(E_{L,S})} = \frac{180.67 \text{ kVA}}{\sqrt{3}(0.48 \text{ kV})} = 217.31 \text{ A}$ $I_{CB} = 1.25 * I_{L,S} = 1.25 * 217.31 \text{ A} = 271.64 \text{ A}$ Frame Size: T8.2 – 600 AF/3P |

| | |
|-------------------|---|
| | <p>Size: Fig15.8 – Unit 2 W = 18" Check: 480 V $I_{SC} = 30,000$ A → OK (see Short Circuit calculations)</p> |
| Subfeeders | <p>Size: Fig 15.8 – Unit 2 W = 18"</p> |

Table 14: A summary of calculations showing the process of finding the final dimensions for the unit substation.

The layout of the unit substation can be found on CAD sheet E7.

Electrical Room Substation Layout

The unit substation must have at least a six foot clearance on all sides from the substation to the room walls. This is a general rule and is done for safety purposes. A schematic of the minimum dimensions is shown below in Figure 1. The schematic is solely for illustration purposes and is not to scale.




Figure 1: Minimum dimensions for electrical room size housing the unit substation.

According to Table 14 and Figure 1, the electrical room must be a minimum of 21.5' x 16.5'. Looking at CAD sheet E5.1, the drawing shows the placement of the electrical room and unit substation. The actual dimensions of the room are 24.83' x 26.33' and the substation is a minimum of 6' away from any wall which satisfies the safety requirements.

Voltage Drop Analysis

Feeder and branch circuit wires were sized to provide less than 3% voltage drop for branch circuits and 2% for feeders. This design criterion was easily met due to the small nature of the building, as well as the centrally located lighting and power panels. The tables below show the process used to estimate voltage drop, based on per length voltage drop values obtained courtesy of Canada Wire and Cable Limited.

| Subfeeder Voltage Drop Analysis | | | | | | | |
|---------------------------------|-------------------|--------------|-----------------|----------------|--------|--------------|--------|
| | Connected Current | Length (Ft.) | Thousand Amp-Ft | VD/1000 Amp-ft | Max VD | Voltage Drop | % VD |
| Motor Sub | 143.195 | 10 | 1.431949 | 0.11 | 8.31 | 0.158 | 0.033% |
| Lighting Sub | 24.979 | 20 | 0.499585 | 0.485 | 8.31 | 0.254 | 0.053% |
| Primary Power Sub | 54.641 | 10 | 0.546408 | 0.462 | 8.31 | 0.252 | 0.053% |
| Secondary Power Sub | 126.094 | 30 | 3.782824 | 0.699 | 3.6 | 2.644 | 0.551% |
| Main Feeder | 252.564 | 5 | 1.262822 | 0.07 | 8.31 | 0.089 | 0.019% |

Table 15: Voltage Drop Analysis for Each Subfeeder

| Lighting Panel Voltage Drop Analysis | | | | | |
|--------------------------------------|--------------------------|------------------|-----------------|--------------|-------------------|
| | Connected Current (Amps) | Max Length (Ft.) | Thousand Amp-Ft | Voltage Drop | % VD for #10 wire |
| L1 | 17.86 | 135 | 2.41 | 2.89 | 1.04% |
| L2 | 9.63 | 85 | 1.02 | 1.23 | 0.44% |
| L3 | 15.29 | 125 | 2.39 | 2.87 | 1.04% |
| L4 | 10.30 | 75 | 0.97 | 1.16 | 0.42% |
| L5 | 15.29 | 135 | 2.58 | 3.10 | 1.12% |
| L6 | 10.30 | 85 | 1.09 | 1.31 | 0.47% |

Table 16: Voltage Drop Analysis for Lighting Panel

| Power Panel Voltage Drop Analysis | | | | | |
|-----------------------------------|--------------------------|------------------|-----------------|--------------|-------------------|
| Circuit | Connected Current (Amps) | Max Length (Ft.) | Thousand Amp-Ft | Voltage Drop | % VD for #12 wire |
| 1 | 12.00 | 110 | 1.32 | 2.53 | 2.11% |
| 2 | 12.00 | 120 | 1.44 | 2.76 | 2.30% |
| 3 | 10.50 | 132 | 1.39 | 2.66 | 2.21% |
| 4 | 10.50 | 120 | 1.26 | 2.42 | 2.01% |
| 5 | 15.00 | 90 | 1.35 | 2.59 | 2.16% |
| 6 | 10.58 | 52 | 0.55 | 1.05 | 0.88% |
| 7 | 6.11 | 88 | 0.54 | 1.03 | 0.86% |
| 8 | 12.00 | 88 | 1.06 | 2.02 | 1.69% |
| 9 | 1.50 | 55 | 0.08 | 0.16 | 0.13% |
| 10 | 3.00 | 67 | 0.20 | 0.39 | 0.32% |
| 11 | 15.00 | 60 | 0.90 | 1.73 | 1.44% |
| 12 | 12.00 | 47 | 0.56 | 1.08 | 0.90% |
| 13 | 12.00 | 105 | 1.26 | 2.42 | 2.01% |
| 14 | 12.00 | 117 | 1.40 | 2.69 | 2.24% |
| 15 | 12.00 | 95 | 1.14 | 2.19 | 1.82% |
| 16 | 13.50 | 125 | 1.69 | 3.23 | 2.70% |
| 17 | 9.04 | 25 | 0.23 | 0.43 | 0.36% |
| 18 | 13.50 | 80 | 1.08 | 2.07 | 1.73% |
| 19 | 15.00 | 40 | 0.60 | 1.15 | 0.96% |
| 20 | 13.58 | 81 | 1.10 | 2.11 | 1.76% |
| 21 | 1.50 | 24 | 0.04 | 0.07 | 0.06% |
| 22 | 3.00 | 24 | 0.07 | 0.14 | 0.12% |
| 23 | 12.00 | 30 | 0.36 | 0.69 | 0.58% |
| 24 | 9.04 | 10 | 0.09 | 0.17 | 0.14% |
| 25 | 12.08 | 24 | 0.29 | 0.56 | 0.46% |
| 26 | 12.00 | 85 | 1.02 | 1.96 | 1.63% |
| 27 | 12.00 | 90 | 1.08 | 2.07 | 1.73% |
| 28 | 12.00 | 80 | 0.96 | 1.84 | 1.53% |
| 29 | 13.50 | 120 | 1.62 | 3.11 | 2.59% |
| 30 | 13.50 | 70 | 0.95 | 1.81 | 1.51% |
| 31 | 15.00 | 55 | 0.83 | 1.58 | 1.32% |
| 32 | 13.58 | 84 | 1.14 | 2.19 | 1.82% |
| 33 | 1.50 | 35 | 0.05 | 0.10 | 0.08% |
| 34 | 3.00 | 35 | 0.11 | 0.20 | 0.17% |
| 35 | 12.00 | 42 | 0.50 | 0.97 | 0.81% |
| 36 | 12.08 | 90 | 1.09 | 2.08 | 1.74% |

Table 17: Voltage Drop Analysis for Power Panel

Short Circuit Calculations Procedure

The short Circuit current at the main secondary feeder (point A) was calculated as follows.

Base kVA=225

Voltage(line to line)= 480V

$$I_s = \frac{225}{\sqrt{3} * .48} = 270.6329 \text{ A}$$

$Z_{\text{utility}} = 0$ (Conservative Assumption)

$Z_{\text{transformer}} = 5.75 \%$

$$I_T = \frac{1.0}{.0575} = 17.3913 \text{ P.U.}$$

$$I_T = 17.3913 \times 271 \text{ A} = 4706.6598 \text{ A}$$

$$I_{\text{motor}} = 4 \times 271 \text{ A} = 1082.53 \text{ A}$$

$$I_{\text{sc,A}} = 5789.1916 \text{ A}_{\text{sym}}$$

This was used as the basis to calculate the short circuit current at each of the subfeeders. The available fault current at B is calculated below as an example.

$$I_{\text{sc,A}} = 5789.1916 \text{ A}_{\text{sym}}$$

$$I_{\text{sc,A}} = \frac{5789.1916}{271} = 21.3955 \text{ P.U.}$$

$$Z_{\text{sys}} = \frac{1}{21.3955} = .0467$$

Assume $x_{\text{system}} = 4 \rightarrow \theta = 76$

$$R_{\text{sys}} = Z_{\text{sys}} * \cos(76) = .01298 \text{ P.U.}$$

$$X_{\text{sys}} = Z_{\text{sys}} * \sin(76) = .0453 \text{ P.U.}$$

Per unit resistance of feeder,

$$R_{\text{ac}} = .1 \Omega / 1000 \text{ ft}$$

$$X_{\text{ac}} = .054 \Omega / 1000 \text{ ft}$$

$$\text{Base Impedence} = \frac{277}{271} = 1.022 \Omega$$

$$R_F = \frac{.002}{1.022} = .00196 \text{ P.U.}$$

$$X_F = \frac{.00108}{1.022} = .00106 \text{ P.U.}$$

$$Z_{\text{total}} = (R_F + R_{\text{sys}}) + j(X_F + X_{\text{sys}}) = .0485 \text{ P.U.}$$

$$I_{\text{sc,B}} = \frac{1.0}{.0485} = 20.645 \text{ P.U.}$$

$$I_{\text{sc,B}} = 20.645 * I_{\text{ref}} = 5594 \text{ A}_{\text{sym}}$$

The available short circuit current at the remaining feeders was determined in same manner shown above. The results of thses calculations are shown in the following table.

| Point A | |
|-------------------------|------------------|
| Base kVA | 225 |
| Voltage (Line to Line) | 480 |
| Rated Secondary Current | 270.63294 |
| $Z_{utility}$ (P.U) | 0 |
| Z_{trans} | 5.75% |
| Z_{ut} | 5.75% |
| I_{trans} (P.U.) | 17.391304 |
| I_{trans} (Amps) | 4706.6598 |
| I_{motor} | 1082.5318 |
| I_{sc} | 5789.1916 |

Table 18: Short Circuit Calculations at A

| | Point B | Point C | Point D | Point E | Point F | Point G |
|-----------------------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Previous I_{sc} | 5789 | 5712 | 5712 | 5712 | 5484 | 1132 |
| Rated Current (A) | 270.6 | 270.6 | 270.6 | 270.6 | 83.3 | 83.3 |
| $Z_{reference}$ | 1.02353 | 1.02353 | 1.02353 | 1.02353 | 1.4 | 1.4 |
| Previous Rated Current (PU) | 21.39 | 21.10 | 21.10 | 21.10 | 65.85 | 13.60 |
| Transformer Z(pu) | 0 | 0 | 0 | 0 | 0.0575 | 0 |
| Z_s | 0.0467 | 0.0474 | 0.0474 | 0.0474 | N/A | 0.0735 |
| R_s | 0.0113 | 0.0115 | 0.0115 | 0.0115 | N/A | 0.0178 |
| X_s | 0.0454 | 0.0460 | 0.0460 | 0.0460 | N/A | 0.0713 |
| R_l | 0.063 | 0.49 | 0.1 | 0.49 | 0 | 0.78 |
| X_l | 0.051 | 0.064 | 0.054 | 0.064 | 0 | 0.065 |
| Length | 10 | 20 | 10 | 10 | 0 | 30 |
| R_F (ohms) | 0.00063 | 0.0098 | 0.001 | 0.0049 | 0 | 0.0234 |
| X_F (ohms) | 0.00051 | 0.00128 | 0.00054 | 0.00064 | 0 | 0.00195 |
| R_F (pu) | 0.000616 | 0.009575 | 0.000977 | 0.004787 | 0 | 0.016238 |
| X_F (pu) | 0.000498 | 0.001251 | 0.000528 | 0.000625 | 0 | 0.001353 |
| R_{total} (pu) | 0.0119 | 0.0210 | 0.0124 | 0.0163 | 0.037307018 | 0.0340 |
| X_{total} (pu) | 0.0459 | 0.0472 | 0.0465 | 0.0466 | 0.063362054 | 0.0733 |
| Z_{total} (pu) | 0.0474 | 0.0517 | 0.0481 | 0.0494 | 0.0735 | 0.0808 |
| I_{sc} (PU) | 21.10 | 19.34 | 20.77 | 20.26 | 13.60 | 12.37 |
| I_{sc} (A) | 5712 | 5235 | 5622 | 5484 | 1132 | 1030 |

Table 19: Short Circuit Calculations at points B-G.

The wire sizes were selected based on ampacity, short circuit current and voltage drop. Wires were selected to provide a voltage drop no greater than 3% for branch circuits and 2 % for feeders. All wires are copper with THW insulation, and based on an ampacity of 75 C. The final wire selections are summarized in Table20, while the sizing criteria are detailed in Table 21. The asymmetrical short circuit current was obtained based on a K factor of 1.3 and a clearing time of 2 cycles. The methodology for the calculations is outlined below.

Demand load calculations

$$Motors\ DL = 1.25 * Largest + 1.0 * Remaining$$

$$Lighting\ DL = 1.25 * Connected\ Load$$

$$Power\ DL = 1.0 * Connected\ Loads$$

Other Calculations

$$I_{CL} = \frac{P_t}{\sqrt{3} V_{Line}}$$

$$I_{asym} = K * I_{SC}$$

| | Min. Wire Sizes | | |
|---------------------------|-----------------------|------------------------------|---------------------------|
| | Ampacity ¹ | I _{sc} ² | Voltage Drop ³ |
| Motor Sub Feeder | 2/0 AWG | #6 AWG | Any |
| Lighting Sub Feeder | #8 AWG | #6 AWG | Any |
| Power Sub Feeder, Primary | #8AWG | #6 AWG | Any |
| Power Sub, Secondary | #8 AWG | #8AWG | #12 AWG |
| Main Secondary | 250 MCM | #6 AWG | Any |
| Lighting Branch Ckts | #10 THW | #10 THW | #10 THW |
| Power Branch Ckts | #12 THW | Any | #12 THW |

Table 20: Summary of the wire sizes selected (highlighted)

1. NFPA 70-87
2. NEC, CSA Type TW75
3. Courtesy of Canada cable. See Voltage Drop Analysis Section.

| | Calculations | | | | | | | | | | |
|----------------------------------|--------------|------|--------|-------|----------|----------|---------------------|------------|------------------------------------|---------|---------|
| | P_T | PF | P_R | P_X | I_{CL} | DL, kVA | Minimum Ampacity, A | Length, ft | $10^3 \text{ Amp} \cdot \text{ft}$ | Isc | Iasym |
| Motor Sub Feeder | 126.26 | 0.85 | 107.10 | 66.87 | 151.87 | 126.26 | 156.30 | 10 | 1.52 | 5622 | 7308.63 |
| Lighting Sub Feeder | 21.352 | 0.98 | 20.92 | 4.25 | 25.68 | 26.69 | 32.10 | 20 | 0.51 | 5235 | 6805.12 |
| Power Sub Feeder, Primary | 45.4275 | 0.9 | 40.88 | 19.80 | 54.64 | 27.71375 | 33.33 | 10 | 0.55 | 5484 | 7128.75 |
| Power Sub, Secondary | 45.4275 | 0.9 | 40.88 | 19.80 | 126.09 | 27.71375 | 76.93 | 30 | 3.78 | 1132 | 1472.24 |
| Main Secondary | 193.04 | 0.87 | 168.91 | 90.92 | 232.19 | 208.38 | 250.64 | 5.00 | 1.16 | 5789.16 | 7525.91 |

Table 21: Ampacity Calculations Summary

References

1. Krarti, Moncef. "AREN 4570 - Electrical Systems for Buildings." *AREN 4570 - Electrical Systems for Buildings*. N.p., n.d. Web. 31 Mar. 2013.
2. Earley, Mark W., Jeffrey S. Sargent, Christopher D. Coache, and Richard J. Roux. *National Electrical Code. Handbook*. Quincy, MA: National Fire Protection Association, 2011. Print.
3. Hughes, S. David. *Electrical Systems in Buildings*. Boston: Delmar Pub., 1988. Print.

Legend and Schedule

- E0 - Legend and Schedule
- E1.1 - Radial Distribution One Line Diagram
- E1.2 - Lighting Panel One Line Diagram
- E1.3 - Power Panel One Line Diagram
- E2 - Riser Diagram
- E3.1 - First Floor Lighting Layout
- E3.2 - Second Floor Lighting Layout
- E3.3 - Third Floor Lighting Layout
- E4.1 - First Floor Power Receptacle Layout
- E4.2 - Second Floor Power Receptacle Layout
- E4.3 - Third Floor Power Receptacle Layout
- E5.1 - First Floor Motor / Electrical Equipment Layout
- E5.2 - Second Floor Motor / Electrical Equipment Layout
- E5.3 - Third Floor Motor / Electrical Equipment Layout
- E6.1 - Lighting Panel Schedule
- E6.2 - Power Panel Schedule
- E7 - Unit Substation Layout
- E8 - Motor Control Center Layout


| Legend | |
|--------|----------------------------------|
| Symbol | Description |
| | Troffers |
| | Occupancy Sensor |
| | 8" Down Light |
| | 8" Emergency Down Light |
| | Circuit Breaker |
| | Switch |
| | Over Current Protection |
| | Fuse |
| | Motor Controller |
| | Transformer |
| | Lighting Panel Board |
| | Power Panel Board |
| | Toilet |
| | Urinal |
| | Light Switch |
| | Wall Outlet |
| | Bathroom Fan |
| | AHU Fan |
| | Water Pump |
| | Chiller |
| | Door |
| | Ground Fault Circuit Interrupter |
| | Exit Sign |
| | Wiring |
| | Sink |
| | Home Run |
| | Motor Control Center |
| | Boiler |
| | Grounding |
| | Exterior Wall Lighting |

| Lighting Schedule | | | | | | | |
|-------------------|------------------------|---------------------------------------|--------------|---------|---------|----------|---|
| Drawing Symbol | Description | Model # | Manufacturer | Wattage | Voltage | Quantity | Notes |
| | Exterior Wall Lighting | 697-WP-MH/1/100-27 7V-BK-C | Shaper | 100 | 277 | 10 | Exterior Lighting near entrances |
| | Troffers | 2-VRM-S-2-54T5-PA3 75-277-LE0C8-GL | ISO | 122 | 277 | 96 | All Troffers per floor are wired together and go to a single fuse on the second floor |
| | Down Lights | PD8H142-E-82H-1G- C-HB128APK | Halo | 45 | 277 | 113 | Downlights for private offices/ conference rooms and hallways. |
| | Emergency Down Lights | PD8H142-REM-82H-1 G-C-HB128APK | Halo | 45 | 277 | 113 | Emergency Down lights must include battery backup. |
| | Exit Signs | ECHX-2-ST-AR-WH | Sure-Lites | 4.50 | 277 | 15 | Exit Signs Should be ordered with the arrows facing the proper direction. |
| | Occupancy Sensors | VAC-DT-2000-R | Greengate | .75 | 277 | 32 | Occupancy Sensors in nearly all spaces help improve energy consumption. |

| Motor Schedule | | | | | | | | | |
|----------------|---------|----------------------------|---------------|----|-------------|------|------------|---------|--------------------------------------|
| Drawing Symbol | Motor # | Description | Manufacturer | HP | # of Motors | PF | Efficiency | Control | Notes |
| | M1 | AHU Supply Fan | Moncef Motors | 25 | 1 | 0.9 | 0.92 | RVNR | Located in utility room on 3rd floor |
| | M2 | AHU Return Fan | Moncef Motors | 15 | 1 | 0.9 | 0.92 | RVNR | Located in utility room on 3rd floor |
| | M3 | CHW Pump | Moncef Motors | 20 | 1 | 0.9 | 0.92 | RVNR | Located in utility room on 2nd floor |
| | M4 | Elevator | Moncef Motors | 20 | 1 | 0.9 | 0.9 | RVR | Located below elevator on 1st floor |
| | M5 | AHU Exhaust | Moncef Motors | 10 | 1 | 0.9 | 0.92 | RVNR | Located in utility room on 3rd floor |
| | M6 | HW Pump | Moncef Motors | 10 | 1 | 0.9 | 0.92 | RVNR | Located in utility room on 2nd floor |
| | M7-M12 | Exhaust Fans (6 Restrooms) | Moncef Motors | 1 | 6 | 0.85 | 0.95 | FVNR | Located in bathrooms on each floor |
| | M13 | Chiller | Carrier | 30 | 1 | 0.90 | 0.9 | RVNR | Located in utility room on 2nd floor |

COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcallatras@yahoo.com


| REVISIONS | | DATE | BY | PROJECT NUMBER |
|-----------|------|-----------|-----|--------------------------|
| REVISION | None | 4/27/2013 | TJM | 3 |
| DRAWN BY: | | | | Travis, Janay, and Matt. |



Legend/Schedules

Office Building
 1234 Downtown
 Right Downtown

Radial Distribution One-Line Diagram




Short Circuit Values
 A: 5789 A
 B: 5712 A
 C: 5235 A
 D: 5622 A
 E: 5484 A
 F: 1132 A
 G: 1030 A

Motors
 M1: AHU Supply Fan
 M2: AHU Return Fan
 M3: CHW Pump
 M4: Elevator
 M5: AHU Exhaust
 M6: Hot Water Pump
 M7: Exhaust Fan
 M8: Exhaust Fan
 M9: Exhaust Fan
 M10: Exhaust Fan
 M11: Exhaust Fan
 M12: Exhaust Fan

COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcillatras@yahoo.com

| | |
|--------------------------|-----|
| REVISIONS | |
| DATE | BY |
| 4/27/2013 | TJM |
| REVISION | |
| None | |
| DRAWN BY: | |
| Travis, Janey, and Matt. | |
| PROJECT NUMBER | |
| 3 | |




Office Building
 1234 Downtown
 Right Downtown

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT


Lighting Panel One-Line Diagram

- Branch Descriptions
 L1: First Floor Troffers
 L2: First Floor Down Lights
 L3: Second Floor Troffers
 L4: Second Floor Down Lights
 L5: Third Floor Troffers
 L6: Third Floor Down Lights



COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcellatrasis@yahoo.com

| REVISIONS | | DATE | BY | PROJECT NUMBER |
|--------------------------|----------|-----------|-----|----------------|
| | REVISION | 4/27/2013 | TJM | 3 |
| | None | | | |
| DRAWN BY: | | | | PROJECT NUMBER |
| Travis, Janay, and Matt. | | | | |



Lighting Panel One-Line Diagram

Office Building
 1234 Downtown
 Right Downtown

SHT NO. 3 OF 18

E1.2

Power Panel One-Line Diagram

Branch Descriptions First Floor



- #1 Conference Room 1A
- #2 Conference Room 1B
- #3 Open Office Area 1A
- #4 Open Office Area 1A / Hallway 1A
- #5 Hallway 1A / Lobby
- #6 Hallway 1B / Lobby
- #7 Hallway 1C / Lobby
- #8 Cafeteria
- #9 Refrigerator 1
- #10 Cafeteria Small Appliance Outlet
- #11 Restrooms 1 / Storage Room 1
- #12 Mechanical and Electrical Room

Second Floor

- #13 Conference Room 2
- #14 Private Office 2A
- #15 Private Office 2B
- #16 Open Office 2
- #17 Stairwell B
- #18 Private Office 2D
- #19 Restrooms 2 / Storage Room 2
- #20 Private Office 2C
- #21 Refrigerator 2
- #22 Small Appliance Second Floor
- #23 Utility Room 2
- #24 Stairwell A
- #25 Hallway 2A

Third Floor


- #26 Conference Room 3
- #27 Private Office 3A
- #28 Private Office 3B
- #29 Open Office 3
- #30 Private Office 3D
- #31 Restrooms 3 / Storage Room 3
- #32 Private Office 3C
- #33 Refrigerator 3
- #34 Small Appliance Third Floor
- #35 Utility Room 3
- #36 Hallway 3A



COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marc@latravis@yahoo.com

| REVISIONS | | DATE | BY | PROJECT NUMBER |
|-----------|----------|-----------|-----|----------------|
| | REVISION | 4/27/2013 | TJM | 3 |
| | None | | | |

DRAWN BY: Travis, Janay, and Matt.



Power Panel One-Line Diagram

Office Building
 1234 Downtown
 Right Downtown

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT


PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

Riser Diagram

Third Floor

Second Floor

First Floor




COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcellatrasvis@yahoo.com



| REVISIONS | |
|-----------|------|
| DATE | BY |
| 4/27/2013 | TJM |
| | None |

DRAWN BY: Travis, Janay, and Matt.
 PROJECT NUMBER: 3




Riser Diagram

Office Building
 1234 Downtown
 Right Downtown

SHT NO. 5 OF 183

E2


First Floor Lighting Layout



PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcellatrasvis@yahoo.com

| REVISIONS | | BY | PROJECT NUMBER |
|-----------|----------|--------------------------|----------------|
| DATE | REVISION | T.J.M | 3 |
| 4/27/2013 | None | | |
| DRAWN BY: | | Travis, Janay, and Matt. | |



First Floor Lighting Layout


Office Building
 1234 Downtown
 Right Downtown

SHT NO. 6 OF 18

E3.1

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

Second Floor Lighting Layout




PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcllstravis@yahoo.com



| REVISIONS | | BY | PROJECT NUMBER |
|-----------|----------|--------------------------|----------------|
| DATE | REVISION | TJM | 3 |
| 4/27/2013 | None | | |
| DRAWN BY: | | Travis, Janay, and Matt. | |



Second Floor Lighting Layout


Office Building
 1234 Downtown
 Right Downtown

SHT NO.7 OF 18

E3.2

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

Third Floor Lighting Layout



PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT


PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcellatrasvis@yahoo.com



| REVISIONS | DATE | BY | PROJECT NUMBER |
|-----------|-----------|-----|----------------|
| REVISION | 4/27/2013 | TJM | 3 |
| None | | | |

DRAWN BY: Travis, Janay, and Matt.




Third Floor Lighting Layout

Office Building
 1234 Downtown
 Right Downtown


SHT NO.8 OF 18

E3.3


First Floor Power Receptacle Layout



COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcellatrasvis@yahoo.com



| REVISIONS | | PROJECT NUMBER |
|-----------|-----|--------------------------|
| DATE | BY | 3 |
| 4/27/2013 | TJM | |
| REVISION | | DRAWN BY: |
| None | | Travis, Janay, and Matt. |




First Floor Power Receptacle Layout

Office Building
 1234 Downtown
 Right Downtown

SHT NO. 9 OF 18

E4.1

Second Floor Power Receptacle Layout




PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT



COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marclat@creek.com

| REVISIONS | | BY | PROJECT NUMBER |
|-----------|----------|--------------------------|----------------|
| DATE | REVISION | TJM | 3 |
| 2/27/2013 | None | | |
| DRAWN BY: | | Travis, Janay, and Matt. | |




Second Floor Power Receptacle Layout

Office Building
 1234 Downtown
 Right Downtown

SHT NO. 10 OF 18


E4.2

Third Floor Power Receptacle Layout



COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcellatrasvis@yahoo.com

| REVISIONS | | BY | PROJECT NUMBER |
|-----------|----------|--------------------------|----------------|
| DATE | REVISION | T.J.M | 3 |
| 4/27/2013 | None | | |
| DRAWN BY: | | Travis, Janay, and Matt. | |




Third Floor Power Receptacle Layout

Office Building
 1234 Downtown
 Right Downtown

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT


PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

First Floor Motor / Electrical Equipment Layout



COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcellatrasvis@yahoo.com

| REVISIONS | | PROJECT NUMBER |
|-----------|----------|--------------------------|
| DATE | REVISION | 3 |
| 4/27/2013 | None | |
| DRAWN BY: | | TRAVIS, JANAY, and MATT. |




First Floor Motor/Electrical Equipment Layout

Office Building
 1234 Downtown
 Right Downtown

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT


Second Floor Motor / Electrical Equipment Layout



COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcellatrasvis@yahoo.com

| REVISIONS | | DATE | BY | PROJECT NUMBER |
|-----------|----------|-----------|-----|----------------|
| | REVISION | 2/27/2013 | TJM | 3 |
| | None | | | |

DRAWN BY: Travis, Janay, and Matt.



Second Floor Motor/Electrical Equipment Layout

Office Building
 1234 Downtown
 Right Downtown


SHT NO. 13 OF 18

E5.2

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT


PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

Third Floor Motor / Electrical Equipment Layout



COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcll@travis@yahoo.com

| REVISIONS | | BY | PROJECT NUMBER |
|-----------|----------|--------------------------|----------------|
| DATE | REVISION | T.J.M | 3 |
| 4/27/2013 | None | | |
| DRAWN BY: | | Travis, Janay, and Matt. | |



Third Floor Motor/Electrical Equipment Layout

Office Building
 1234 Downtown
 Right Downtown


PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

Lighting Panel Schedule

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

| LOAD DESCRIPTION | A (Amps) | B (Amps) | C (Amps) | CB |
|------------------|----------|----------|----------|--------|
| L1 | 20.35 | | | 30A/1P |
| L2 | | 12.04 | | 30A/1P |
| L3 | | | 19.11 | 30A/1P |



| CB | A (Amps) | B (Amps) | C (Amps) | LOAD DESCRIPTION |
|--------|----------|----------|----------|------------------|
| 30A/1P | 12.87 | | | L4 |
| 30A/1P | | 19.11 | | L5 |
| 30A/1P | | | 12.87 | L6 |


| LOAD TOTALS (Amps) | |
|--------------------|-------|
| LOAD A, T | 33.22 |
| LOAD B, T | 31.15 |
| LOAD C, T | 31.98 |

| % UNBALANCED | |
|--------------|------|
| %AB = | 6.63 |
| %BC = | 2.60 |
| %CA = | 3.71 |

COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcellatrasvis@yahoo.com



| REVISIONS | |
|--------------------------|-------|
| DATE | BY |
| 4/27/2013 | T.J.M |
| | None |
| PROJECT NUMBER | |
| 3 | |
| DRAWN BY: | |
| Travis, Janey, and Matt. | |



Lighting Panel Schedule

Office Building
 1234 Downtown
 Right Downtown

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT


PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

Power Panel Schedule

COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcillatavis@yahoo.com



| LOAD DESCRIPTION | A (Amps) | B (Amps) | C (Amps) | CB |
|------------------------------------|----------|----------|----------|--------|
| #1 Conference Room 1A | 12 | | | 20A/1P |
| # Conference Room 1B | | 12 | | 20A/1P |
| #8 Cafeteria | | | 12 | 20A/1P |
| #12 Mechanical and Electrical Room | 12 | | | 20A/1P |
| #13 Conference Room 2 | | 12 | | 20A/1P |
| #14 Private Office 2A | | | 12 | 20A/1P |
| #3 Open Office Area 1 A | 10.5 | | | 20A/1P |
| #4 Open Office Area/Hallway 1A | | 10.5 | | 20A/1P |
| #6 Hallway 1B/Lobby | | | 10.75 | 20A/1P |
| #9 Refrigerator 1 | 1.5 | | | 20A/1P |
| #21 Refrigerator 2 | | 1.5 | | 20A/1P |
| #33 Refrigerator 3 | | | 1.5 | 20A/1P |
| #19 Restrooms 2/Storage Room 2 | 15 | | | 20A/1P |
| #20 Private Office 2C | | 13.58 | | 20A/1P |
| #5 Hallway 1A/Lobby | | | 15 | 20A/1P |
| #29 Open Office 3 | 13.5 | | | 20A/1P |
| #25 Hallway 2A | | 12.08 | | 20A/1P |
| #16 Open Office 2 | | | 13.5 | 20A/1P |
| SUM: | 64.5 | 61.65 | 64.75 | |



| CB | A (Amps) | B (Amps) | C (Amps) | LOAD DESCRIPTION |
|--------|----------|----------|----------|--------------------------------------|
| 20A/1P | 12 | | | #15 Private Office 2B |
| 20A/1P | | 12 | | #23 Utility Room 2 |
| 20A/1P | | | 12 | #26 Conference Room 3 |
| 20A/1P | 12 | | | #27 Private Office 3A |
| 20A/1P | | 12 | | #28 Private Office 3B |
| 20A/1P | | | 12 | #35 Utility Room 3 |
| 20A/1P | 9.04 | | | #17 Stairwell B |
| 20A/1P | | 9.04 | | #24 Stairwell A |
| 20A/1P | | | 6.11 | #7 Hallway 1C/Lobby |
| 20A/1P | 3 | | | #10 Cafeteria Small Appliance Outlet |
| 20A/1P | | 3 | | #22 Small Appliance Second Floor |
| 20A/1P | | | 3 | #34 Small Appliance Third Floor |
| 20A/1P | 13.58 | | | #32 Private Office 3C |
| 20A/1P | | 15 | | #31 Restrooms 3/Storage Room 3 |
| 20A/1P | | | 15 | #11 Restrooms 1/Storage Room 1 |
| 20A/1P | 12.08 | | | #36 Hallway 3A |
| 20A/1P | | 13.5 | | #30 Private Office 3D |
| 20A/1P | | | 13.5 | #18 Private Office 2D |
| SUM: | 61.69 | 64.54 | 61.61 | |

| LOAD TOTALS (Amps) | |
|--------------------|--------|
| LOAD A, T | 126.19 |
| LOAD B, T | 126.19 |
| LOAD C, T | 126.36 |

| % UNBALANCED | |
|--------------|------|
| %AB = | 0 |
| %BC = | 0.14 |
| %CA = | 0.14 |

| REVISIONS | | BY TJM | PROJECT NUMBER 3 |
|-----------|----------|-----------|---------------------|
| DATE | REVISION | | |
| 4/27/2013 | None | | |

DRAWN BY: Travis, Janay, and Matt.


Power Panel Schedule

Office Building
 1234 Downtown
 Right Downtown

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

Unit Substation Layout




PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE
 BOULDER, COLORADO 80304
 303.553.4822
 marcellatrasvis@yahoo.com



| REVISIONS | | DATE | BY | PROJECT NUMBER |
|-----------|----------|--------------------------|-----|----------------|
| | REVISION | 2/27/2013 | TJM | |
| | None | | | |
| DRAWN BY: | | Travis, Janay, and Matt. | | |
| | | PROJECT NUMBER | | 3 |




Unit Substation Layout

Office Building
 1234 Downtown
 Right Downtown

PRODUCED BY AN AUTODESK EDUCATIONAL PRODUCT

Motor Control Center Layout




COLORADO REMODELING ENGINEERS FOR ENVIRONMENTAL KINDNESS
 1260 ELDER AVE.
 BOULDER, COLORADO 80304
 303.533.4822
 marcellatrasvis@yahoo.com



| REVISIONS | | BY | PROJECT NUMBER |
|-----------|----------|-----|----------------|
| DATE | REVISION | TJM | 3 |
| 2/27/2013 | None | | |

DRAWN BY: Travis, Janay, and Matt.




Motor Control Center Layout

Office Building
 1234 Downtown
 Right Downtown

DESCRIPTION

The 697-WP features a compact cast Aluminum Hood Downlight.

Exterior Entrance Lighting



| | | |
|-------------|--|------|
| Catalog # | | Type |
| Project | | |
| Comments | | Date |
| Prepared by | | |

SPECIFICATION FEATURES

Material

Cast aluminum construction with clear tempered refractive glass for MH incandescent or 1/8" white acrylic for incandescent and CFL lamps. Optional clear tempered glass for full cut-off.

Finish

Premium TGIC polyester powder coat paint, 2.5 mil nominal thickness for superior protection against fade and wear. Standard: Black (BK) or White (WH). Premium: Aluminum Paint (ALP), Bronze Metallic Paint (BM), Gold Metallic Paint (GM), Dark Platinum Paint (DP), Graphite Metallic Paint (GRM), Grey Paint (GY) or Custom Color (CC).

Optics

Refer to www.shaperlighting.com for complete photometrics.

Ballast

Integral electronic HPF, multi-volt 120/277V (347V Canada), thermally protected with end-of-life circuitry to accommodate the specified lamp wattage. Metal halide ballasts are electronic HPF, multi-volt 120/277V for the specified lamp wattage. 347V ballasts for metal halide - Contact factory.

Lamp

One (1) 26W, 32W (GX24q-3) or 42W (GX24q-4) 4-pin triple tube CFL lamp or one (1) 50W, 70W or 100W ED-17 metal halide lamp or one (1) 100W A-19 lamp. CFL socket injection molded plastic. INC socket fired ceramic rated for 660W-250V. Metal halide socket ceramic pulse-rated, 4KV. Lamps furnished by others.

Installation

Supplied with a mounting back for a standard 4" J-box or stucco ring. Optional rear (through wall) feed conduit mounting.

Options

Rear (through wall) Feed Conduit Mounting (C), Clear Tempered Glass Lense - for full cut-off Quartz (TGL) [Dark Sky Compliant], Restrike (MH only) (QR).

Labels

U.L. and C.U.L. listed for wet location.

Modifications

Shaper's skilled craftspeople with their depth of experience offer the designer the flexibility to modify standard exterior wall luminaires for project specific solutions. Contact the factory regarding scale options, unique finishes, mounting, additional materials/colors, or decorative detailing.



697-WP SERIES

Exterior Wall Luminaire Hood Downlight



Shaper Lighting certifies that its products satisfy the requirements of Section 1605 of the American Recovery and Reinvestment Act (also known as the ARRA Buy American provision).



Shaper offers a selection of exterior luminaires that are "Dark Sky Compliant". The IESNA (Illuminating Engineering Society of North America) defines Full Cut-Off as fixtures with light distributions of 0% candela at 90° and 10% at 80°. Full Cut-Off luminaires carry the endorsement of the International Dark-Sky Association (IDA) for their effectiveness in limiting the detrimental effects of sky glow, also referred to as "Light Pollution". Many exterior luminaires offer a clear, tempered glass option that meets the IES criteria for Full Cut-Off.

Troffer Lighting



FAIL-SAFE

DESCRIPTION

The VRM combines a low-profile, surface modular design with the latest in energy-efficient technology. The dihedral recessed top design allows for cooler fixture operation. Other features include a die-formed housing, surface or stem mounting (single or continuous row), full seam-welded corners and a broad selection of attractive door frames. The durable, versatile VRM is perfect for use in commercial spaces, schools, hospitals, correctional or industrial facilities and high volume public access areas.

| | | |
|-------------|--|------|
| Catalog # | | Type |
| Project | | |
| Comments | | Date |
| Prepared by | | |

SPECIFICATION FEATURES

Construction

Housing is die-formed, code gauge, prime cold-rolled steel. Smooth sides permit flush joint for continuous row mounting. Full seam-welded corners. Dihedral recessed top design insures cooler ballast operation. Die-formed captive lampholder bracket fully encloses wiring permitting easy lampholder replacement. Ballast covers easily removed without tools.

Finish

Painted after fabrication. Electrostatically-applied baked white polyester powder enamel finish. Multistage cleaning cycle, iron phosphate coating with rust inhibitor. Conveyorized application and baking timing accurately controlled at an elevated temperature.

Frame/Shielding

Die-formed, heavy gauge, flat steel door with reinforced mitered corners and baked white enamel finish. Positive light seals. Frame and lens are secured to housing with 4 or 6T20 stainless steel TORX® screws.

Electrical*

Ballasts are CBM/ETL Class "P" and are positively secured by mounting bolts. Pressure lock lampholders.

Hinging/Latching

Positive cam action steel latches with baked white enamel finish. Safety lock hinges allow hinging and latching either side.

Labels


UL/CUL listed for damp locations.




2VRM

2x4
Vandal Resistant

SURFACE
Lens Troffer




MOUNTING DATA




DOOR FRAMES

2VRM
Flat, White
Steel



LAMP CONFIGURATIONS



TORX® is a registered trademark of Camcar Division of Textron Inc.

ENERGY DATA

Input Watts:
EB Ballast & STD Lamps
232 (61)
432 (122)

ES Ballast & STD Lamps
232 (71)
432 (142)

Luminaire Efficacy Rating

LER = FL-71
Catalog Number:
Yearly Cost of 1000 lumens:
3000 hrs at .08 KWH = \$3.38

* Reference the lamp/ballast data in the Technical Section for specific lamp/ballast requirements.




ORDERING INFORMATION

SAMPLE NUMBER: VRM-432A

| Width | Series | Door Type | No. of Lamps | Wattage (Length) | Lens Type | Voltage | Ballast Type | Options (Add as Suffix) | Accessories (Order Separately) |
|--------|--|-----------|-----------------------------------|--|-----------|---------|---|--|--|
| 2 | VRM | | | | | | | | |
| 2 = 2' | VRM | | 2, 3 or 4 Lamps (Not included) | 28T5 =28W T5 (48") 32 =32W T8 (48") 54T5 =54W T5HO (48") | | | LEOC8= Energy Saving Ballast (T8 Lamp only) EB = Generic Electronic Ballast No. of Ballasts 1 or 2 Lamp Size 8 =T8 <small>(For specific Electronic Ballast specify Brand and Catalog Number.)</small> | GL= Internal Single Element Fusing GM= Dual Element Fusing EL4= Emergency Lighting, self contained SMB= Side-Mounted Ballast for Stem Applications (Recommended for 4-Point Suspension) RIF1 = Radio Interference Suppressor EKO= End Plate with 7/8" KO (Required for Continuous Row Mounting) RLS= Rotor-Lock Socket (T8 Lamps only) 6S= Six TORX®-head Screws (3 per side) SC =Safety Chain | |
| | Standard = Flat White Steel Door (Leave Blank) | | | ACTF140= .140 Thick ACTF187= .187 Thick PA375 = .250 polycarbonate with .125 prismatic overlay (standard with 6S option) | | | | | VRSD=T20 Center Pin Tamperproof TORX®-head bit |
| | | | | 120=120V 277=277V 347=347V UNV=Universal Voltage (120-277V) | | | | | |

PHOTOMETRICS

Candlepower Distribution



Test No. M-2071
2VRM-340-ACTF140
 Lamp=F40T12/CW
 Lumens=3150
 Spacing Criteria
 $\perp=1.4$ $\parallel=1.2$
 Efficiency=70.3%

--- \perp
 --- \parallel

Candlepower

| Deg. | \perp | \parallel |
|------|---------|-------------|
| 0 | 2659 | 2659 |
| 5 | 2650 | 2663 |
| 15 | 2559 | 2650 |
| 25 | 2373 | 2587 |
| 35 | 2056 | 2391 |
| 45 | 1553 | 1839 |
| 55 | 986 | 1127 |
| 65 | 541 | 526 |
| 75 | 253 | 259 |
| 85 | 105 | 111 |
| 90 | 0 | 0 |

Typical VCP Percentages

| Room Size (in Feet) | Height Along \parallel | | Height Across \perp | |
|---------------------|--------------------------|-------|-----------------------|-------|
| | 8'6" | 10'0" | 8'6" | 10'0" |
| 20 x 20 | 68 | 71 | 67 | 70 |
| 30 x 30 | 60 | 65 | 60 | 64 |
| 30 x 60 | 52 | 56 | 51 | 55 |
| 60 x 30 | 62 | 66 | 61 | 66 |
| 60 x 60 | 52 | 55 | 51 | 54 |

Zonal Lumen Summary

| Zone | Lumens | %Lamp | %Luminaire |
|--------|--------|-------|------------|
| 0-30 | 2136 | 22.6 | 32.2 |
| 0-40 | 3540 | 37.5 | 53.3 |
| 0-60 | 5746 | 61.1 | 56.9 |
| 0-90 | 6641 | 70.3 | 100.0 |
| 90-180 | 0 | 0.0 | 0.0 |
| 0-180 | 6641 | 70.3 | 100.0 |

Coefficient of Utilization

| rc | 80% | | | | 70% | | | 50% | | 30% | | 10% | | 0% |
|-----|-----|----|----|----|-----|----|----|-----|----|-----|----|-----|----|----|
| | rw | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 10 | 50 | 10 | 50 | 10 | 0 |
| RCR | | | | | | | | | | | | | | |
| 0 | 84 | 84 | 84 | 84 | 82 | 82 | 82 | 78 | 78 | 75 | 75 | 72 | 72 | 70 |
| 1 | 77 | 74 | 71 | 69 | 73 | 70 | 68 | 70 | 66 | 67 | 64 | 64 | 62 | 60 |
| 2 | 71 | 66 | 61 | 58 | 64 | 60 | 57 | 62 | 56 | 60 | 54 | 58 | 53 | 52 |
| 3 | 65 | 58 | 53 | 49 | 57 | 52 | 49 | 55 | 48 | 53 | 47 | 52 | 46 | 45 |
| 4 | 60 | 52 | 47 | 42 | 51 | 46 | 42 | 50 | 41 | 48 | 41 | 47 | 40 | 39 |
| 5 | 56 | 47 | 41 | 37 | 46 | 41 | 37 | 45 | 36 | 44 | 36 | 42 | 36 | 34 |
| 6 | 51 | 43 | 37 | 32 | 42 | 36 | 32 | 41 | 32 | 40 | 32 | 39 | 32 | 30 |
| 7 | 48 | 39 | 33 | 29 | 38 | 33 | 29 | 37 | 29 | 36 | 28 | 35 | 28 | 27 |
| 8 | 45 | 36 | 30 | 26 | 35 | 30 | 26 | 34 | 26 | 33 | 26 | 32 | 25 | 24 |
| 9 | 42 | 33 | 27 | 23 | 32 | 27 | 23 | 31 | 23 | 31 | 23 | 30 | 23 | 22 |
| 10 | 39 | 30 | 25 | 21 | 30 | 25 | 21 | 29 | 21 | 28 | 21 | 28 | 21 | 20 |

rc=Ceiling reflectance, rw=W all reflectance, RCR=Room cavity ratio
 CU Data Based on 20% Effective Floor Cavity Reflectance.

DownLighting: Emergency lights Require Batteries



HALO Commercial

DESCRIPTION

Recessed 8 inch aperture lens downlight for one horizontal 26W double twin tube or 26/32/42W triple twin tube compact fluorescent lamp. Fixture is suitable for commercial construction and wet location listed. Insulation must be kept 3" from top and sides of housing. Universal input electronic ballast with dimming and emergency options.

| | | |
|-------------|--|------|
| Catalog # | | Type |
| Project | | |
| Comments | | Date |
| Prepared by | | |

SPECIFICATION FEATURES

MECHANICAL

Frame
Boat shaped galvanized steel frame with 1/2" plaster lip accommodates ceilings up to 2" thick. May be used for new construction or remodeling installations. Provided with (2) remodel clips to secure frame when installed from below the ceiling.

Mounting Brackets
Bar hanger receivers adjusts 2" vertically from above the ceiling or thru the aperture. Use with No Fuss™ bar hangers or with 1/2" EMT. Removable to facilitate installation from below the ceiling.

No Fuss™ Bar Hangers
Pre-installed and centered bar hanger locks to tee grid with a screwdriver or pliers. Centering marks on the bar hanger mechanism allows consistent positioning of fixtures.

OPTICAL

Reflector
One piece aluminum reflector secures lens in place with integrated spring clips for a visually comfortable optic and allows for tool-less lens exchange from below the ceiling. Available with clear, diffuse, prismatic, fresnel or drop opal glass lens. Optional cross blade louver provides sharper cutoff to lamp. Self flanged standard.

- Specular Reflectors - Polished flange standard with white painted flange option.
- Baffles and White Reflector - White painted flange standard.

Trim Retention
Reflector is retained with two torsion springs and held tightly to the finished ceiling surface.

ELECTRICAL
Junction Box
(6) 1/2" and (2) 3/4" trade size pry outs positioned to allow straight conduit runs. Listed for (12) #12 AWG (six in, six out) 90°C conductors and feed thru branch wiring.

Lamp Socket
4-pin G24q base accepts (1) 26W DTT or 26/32/42W TTT lamp.

Socket Housing
Galvanized steel socket housing attached securely to reflector with captive thumbscrew. Vents provide effective lamp thermal management.

Control Gear
Universal 120V - 277V UNV or 347V input electronic ballast for 26/32/42W compact fluorescent lamp.

Emergency Battery Pack
REM - Remote emergency test switch. Housing includes 120V/277V, 60Hz dual-tap battery pack provides 90 minutes of emergency illumination. Long life maintenance free sealed nickel cadmium batteries recharge fully in 24 hours. REM configuration includes prewired and attached remote test switch plate and indicator light. REM option is the standard emergency configuration, and is compatible with all standard reflector options, ordered separately.

IEM - Integral emergency test switch. Housing includes 120V/277V, 60Hz dual-tap battery pack provides 90 minutes of emergency illumination. Long life maintenance free sealed nickel cadmium batteries recharge fully in 24 hours. IEM configuration includes a prewired integral

emergency test switch and indicator light that are both accessible inside the reflector. The IEM option requires "EM" designated reflectors only, ordered separately.

Emergency Battery Pack - Average Lamp Lumen Ratings

REM option: 26W 425lm, 32W 600lm, 42W 750lm

IEM option: 26W 810lm, 32W 910lm, 42W 1040lm

(Note: average lamp lumens are based upon REM and IEM manufacturer ratings. Delivered lumens depend upon trim; refer to trim photometry to factor delivered lumens).

Code Compliance

- Thermally protected and cULus listed for wet locations.
- IP44 rated for lens trims
- NFPA Life Safety (Emergency Battery Pack)
- EMI/RFI per FCC Title 47 CFR, Part 18, non consumer limits.
- Peel down wattage label from 42W to 32W and 26W. Allows de-rating to set max. relamp wattage per project specifications (multi-wattage housings only).
- DR - De-rated label housings are wattage specific for 26/32W or 26W.
- High efficacy luminaire may be used to meet IECC, ASHRAE, and Title 24 commercial standards.



**PD8H142
82H**

(1) 26W DTT
26/32/42WTTT

Compact Fluorescent

8-Inch Aperture
Lens Downlight


New Construction or
Remodel
Non-IC

ENERGY DATA

| PD8H142E, PD8CPH142E | |
|---|--|
| MIN. STARTING TEMP -5°F / -20°C | SOUND RATING CLASS A |
| EMI/RFI EMISSIONS FCC 47CFR PART 18 NON-CONSUMER LIMITS | |
| INPUT FREQUENCY 50/60 Hz | POWER FACTOR > 0.98 |
| THD < 10% | INPUT VOLTAGE 120V - 277V ±10% |
| CREST FACTOR < 1.7 | |
| OPERATING FREQUENCY > 40kHz | UL LISTED CLASS P, TYPE 1 OUTDOOR, CSA OR C/UL CERTIFIED |
| CFQ26W/G24Q | Input Power 28W |
| | Input Current 0.50A @ 120V |
| | Input Current 0.22A @ 277V |
| | Ballast factor 1.00 |
| CFTR26W/GX24Q | Input Power 28W |
| | Input Current 0.50A @ 120V |
| | Input Current 0.22A @ 277V |
| | Ballast factor 1.00 |
| CFTR32W/GX24Q | Input Power 35W |
| | Input Current 0.50A @ 120V |
| | Input Current 0.22A @ 277V |
| | Ballast factor .98 |
| CFTR42W/GX24Q | Input Power 45W |
| | Input Current 0.50A @ 120V |
| | Input Current 0.22A @ 277V |
| | Ballast factor .96 |

| PD8H1423E | |
|---|---|
| MIN. STARTING TEMP 0°F / -18°C | SOUND RATING CLASS A |
| EMI/RFI EMISSIONS FCC 47CFR PART 18 NON-CONSUMER LIMITS | |
| INPUT FREQUENCY 60 Hz | POWER FACTOR > 0.98 |
| THD < 10% | INPUT VOLTAGE 347VAC ±10% |
| OPERATING FREQUENCY 50-60 kHz | cULUS LISTED CLASS P, TYPE 1 OUTDOOR, TYPE CC |
| CFQ26W/G24Q | Input Power 31W |
| | Input Current 0.09A @ 347V |
| | Ballast factor 1.02 |
| | Crest factor < 1.6 |
| CFTR26W/GX24Q | Input Power 31W |
| | Input Current 0.09A @ 347V |
| | Ballast factor 1.02 |
| | Crest factor < 1.6 |
| CFTR32W/GX24Q | Input Power 36W |
| | Input Current 0.11A @ 347V |
| | Ballast factor 0.98 |
| | Crest factor < 1.5 |
| CFTR42W/GX24Q | Input Power 50W |
| | Input Current 0.15A @ 347V |
| | Ballast factor 1.00 |
| | Crest factor < 1.5 |

DIMENSIONS




ORDERING INFORMATION

SAMPLE NUMBER: PD8H142E 82H1GC

Order housing, reflector and lamp separately for a complete luminaire.

| | | | | | |
|---|--|---|---|---|---|
| <p>Housing Multi-Wattage PD8H142 = 8 Inch horizontal (1) 26/32/42W DTT/TTT CFL PD8CPH142 = 8 Inch horizontal (1) 26/32/42W DTT/TTT CFL, CCEA listed (Chicago Plenum)</p> <p>De-Rated Label PD8H132 = 8 Inch horizontal (1) 26/32W DTT/TTT CFL PD8CPH132 = 8 Inch horizontal (1) 26/32W DTT/TTT CFL, CCEA listed (Chicago Plenum)</p> <p>PD8H126 = 8 Inch horizontal (1) 26W DTT/TTT CFL PD8CPH126 = 8 Inch horizontal (1) 26W DTT/TTT CFL, CCEA listed (Chicago Plenum)</p> | <p>Ballast Option E = 120V - 277V 50/60Hz UNV REM = 120V/277V 60Hz dual-tap emergency battery ballast with remote test switch plate 3E = 347V, 50/60Hz 1DMARKX = 5% two-wire (26/32/42W) dimming, 120V 2DMARKX = 5% two-wire (26/32/42W) dimming, 277V EDMARK7 = 5% 0-10V discrete two-wire (26/32/42W) dimming, 120-277V 1DMARKXREM = 5% two-wire (26/32/42W) dimming, 120V; with REM emergency option 2DMARKXREM = 5% two-wire (26/32/42W) dimming, 277V; with REM emergency option EDMARK7REM = 5% 0-10V discrete two-wire (26/32/42W) dimming, 120-277V; with REM emergency option</p> <p>Integral Emergency Ballast Option IEM = 120/277V 60Hz dual-tap, Integral Emergency battery ballast with test switch through reflector* 1DMARKXIEM = 5% two-wire (26/32/42W) dimming, 120V; with IEM emergency option* 2DMARKXIEM = 5% two-wire (26/32/42W) dimming, 277V; with IEM emergency option* EDMARK7IEM = 5% 0-10V discrete two-wire (26/32/42W) dimming, 120-277V; with IEM emergency option* *Requires "EM" reflectors only, ordered separately</p> | <p>Reflector 82H = 8" horizontal 82HEM = 8" Horizontal, Emergency (required with IEM ballast option)</p> | <p>Regressed Lens Option 1G=Prismatic Glass 2G=Diffuse Glass 3G=Clear Glass 4G=Fresnel Glass</p> <p>Finish Option C=Specular Clear G=Specular Gold H=Semi Specular Clear W=White (White Flange) BB = Black baffle (White Flange) WB = White baffle (White Flange)</p> | <p>Flange Option Blank=Polished Flange (C, G, H) Blank=White Flange (W, BB, WB) WF=White Flange (C, G, H)</p> | <p>Accessories HB128APK = L channel hanger bar, 26", 'No-Fuss', pair (replacement) RMB22 = 22" long wood joist mounting bars</p> |
|---|--|---|---|---|---|

PHOTOMETRY



| Candela Distribution | |
|----------------------|---------|
| Degrees Vertical | Candela |
| 0* | 782 |
| 5 | 789 |
| 15 | 798 |
| 25 | 722 |
| 35 | 552 |
| 45 | 359 |
| 55 | 166 |
| 65 | 39 |
| 75 | 1 |
| 85 | 0 |
| 90 | 0 |

*CBCP

| Luminance | |
|-----------------------------------|-------------------|
| (Average Candela/M ²) | |
| Degree | Avg. 0° Luminance |
| 45 | 11744 |
| 55 | 6285 |
| 65 | 1818 |
| 75 | 63 |
| 85 | 0 |

| Cone of Light Footcandles | | | |
|-------------------------------|---------------------------|------------|---------|
| Distance to Illuminated Plane | Initial Nadir Footcandles | Beam (ft.) | |
| | | L Length | W Width |
| 5.5' | 26 | 6.5 | 7.1 |
| 7' | 16 | 8.3 | 9 |
| 8' | 12 | 9.5 | 10.3 |
| 9' | 10 | 10.6 | 11.6 |
| 10' | 8 | 11.8 | 12.9 |
| 12' | 5 | 14.2 | 15.5 |
| 14' | 4 | 16.5 | 18 |

Beam diameter is to 50% of maximum footcandles, rounded to the nearest half-foot. Footcandle values are initial, apply appropriate light loss factors where necessary.

| Zonal Lumen Summary | | | |
|---------------------|---------|--------|-----------|
| Zone | Lumens | % Lamp | % Fixture |
| 0-30 | 640.21 | 26.70 | 44.20 |
| 0-40 | 990.80 | 41.30 | 68.40 |
| 0-60 | 1398.25 | 58.30 | 96.60 |
| 0-90 | 1447.59 | 60.30 | 100.00 |

Note: Specifications and Dimensions subject to change without notice.

Visit our web site at www.cooperlighting.com

DESCRIPTION

The ECHX Series Surface and recessed mount Edge-lit Exits, provide an attractive yet easy to install universal edge-lit exit sign. The crystal clear wedge shape lens panel with white background standard provides excellent light distribution, exit visibility and easy installation. Long life, energy efficient LED lamps reduce energy costs and eliminate routine lamp maintenance. Durable extruded aluminum construction, attractive styling and high efficiency illumination make this series compatible in commercial, institutional and multi-housing applications.

| | | |
|-------------|--|------|
| Catalog # | | Type |
| Project | | |
| Comments | | Date |
| Prepared by | | |

SPECIFICATION FEATURES

Electrical

- Dual Voltage Input 120/277 VAC, 60Hz
- Line-latching
- Solid-state Voltage Limited Charger
- Solid-state Switching
- Brownout Circuit
- Test Switch / Power Indicator Light

Lens

- Injection molded, UV stabilized high impact, silk screened acrylic panels
- Bright red exit letter colors
- Panels customized with full stroke arrows for selected directional indicators
- White insert background included with single or double face exit panels
- Edge reflector for optimized efficiency and visibility

Battery

- Sealed Nickel Cadmium.
- Maintenance-Free, Long-Life
- Full Recharge Time, 24 hrs. (Max.)

Housing Construction

- Anodized extruded aluminum housing
- Designer white textured finish available
- Components are of snap-fit construction to facilitate easy installation
- All components including battery and electronics are located inside the exit housing (surface) or the back (recessed).
- Die cast aluminum canopy with mounting screws included with all surface exits
- Surface mount exit can be universally mounted, ceiling, wall, or end, with Tri-Mount™ System

- Universal J-box mounting plate on surface mount exit
- Recessed Mount Unit can be installed in dry wall or drop thru ceilings

Code Compliance

- UL 924 Listed
- Life Safety NFPA 101
- NEC/OSHA
- Most State and Local Codes
- City of Chicago fire code
- Chicago Plenum Approved

Warranty


- Exit: 1-Year
- Battery: 15-year pro-rated (Nickel Cadmium)

Lamp Data


- AC LED: Long life LED lamps provide uniform diffused illumination
- DC: LED DC lamps



Surface Mount



Recessed Mount



ORDERING INFORMATION

HOUSING - SAMPLE NUMBER: ECHX72SARLWH

| Family | LED | Mounting / Trim Options |
|------------------------------------|--|--|
| ECHX =Chicago Edge-Lit Exit Series | 6=LED Lamps 7=LED Lamps, Self-powered | RH =Recessed SHA =Surface, Brushed Aluminum SHWH =Surface, White |

TRIM - SAMPLE NUMBER: ECHX72SARLWH

| Family | Face Options | Mounting Option | Arrow Options | Trim Finish | Stairs Option |
|------------------------------------|----------------------|-----------------------------|--|--|---|
| ECHX =Chicago Edge-Lit Exit Series | 1=Single 2=Double | ST =Surface RT =Recessed | [Blank] =No Arrow AR =Arrow Right (Single Face only) AL =Arrow Left (Single Face only) DA =Double Arrow ARL =Arrow Right/Left (Double Face only) | [Blank] =Brushed Aluminum WH =White | [Blank] =Exit Sign -Stair =Stair Sign (include dash) |

ECHX Series

EDGE-LIT EXITS
SE LF POWERE D
EMER GENC Y
LED LAMPS
CHICA GO EXIT LIGHTIN G

TOTALLY PREDICTABLE
RELIABILITY

ENERGY DATA

Maximum power consumption under all charge conditions:

LED Exits - Red

Input Power:
120V = 4.5W
277V = 4.9W
Input Current (Max.):
120V = 0.04A
277V = 0.02A

TECHNICAL DATA

Lamps

The ECHX Series Exits use energy efficient, long-life LEDs to provide uniform diffuse illumination of the exit face. These white LEDs require no maintenance. The low operating costs and zero maintenance requirement makes LED lamps the wisest choice for exit signs today. Emergency illumination is provided by LED lamps.

Housing Construction

Rugged, durable, anodized extruded aluminum materials are used in the ECHX Series Exits. All structural components are designed with reinforcing ribs to add additional rigidity and to maximize structural integrity. These materials are impact and scratch-resistant. All components are designed to be of snap-fit construction to facilitate easy installation. ECHX Series surface mount exits can be wall-, ceiling- or end-mounted. A Die-Cast Aluminum mounting canopy with installation screws is included. Recessed mount exits can be installed in drywall or drop-thru ceilings.

Lens

Trim panels for the ECHX Series Edgelit Exits are injection-molded from impact-resistant clear acrylic. Silk screened red letters, with white background insert is standard with all panels. Panels are customized with full stroke arrows for selected directional indicators. The edge reflector further enhances visibility.

Line-Latched (Self-Powered Only)

Sure-Lites' line-latched electronic circuitry makes installation easy and economical. A labor efficient AC activated load switch prevents the lamps from turning on during installation to a non-energized AC circuit. Line-latching eliminates the need for a contractor's return to a job site to connect the batteries when the building's main power is turned on.

Solid-State Charger (Self-Powered Only)

Supplied with a 120/277 VAC, voltage regulated solid-state charger, the battery is recharged immediately upon restoration of AC current after a power failure. The charge circuit reacts to the condition of the battery in order to maintain peak battery capacity and maximize battery life. Solid-state construction recharges the battery following a power failure in accordance with UL 924.

Brownout Circuit (Self-Powered Only)

The brownout circuit on Sure-Lites' exits monitors the flow of AC current to the exit and activates the emergency lighting system when a predetermined reduction of AC power occurs. This dip in voltage will cause most ballasted fixtures to extinguish causing loss of normal lighting even though a total power failure has not occurred.

Solid-State Transfer (Self-Powered Only)

The ECHX Series Exit incorporates solid-state switching which eliminates corroded and pitted contacts or mechanical failures associated with relays. The switching circuit is designed to detect a loss of AC voltage and automatically energizes the lamps using DC power. Upon restoration of AC power, the DC power will be disconnected and the charger will automatically recharge the battery.

Test Switch/Power Indicator Light (Self-Powered Only)

A test switch located on the side of the exit (surface) or on the trim plate (recessed) permits the activation of the emergency circuit for a complete operational systems check. The Power Indicator Light provides visual assurance that the AC power is on.

Sealed Nickel Cadmium Battery (Self-Powered Only)

Sure-Lites sealed nickel cadmium batteries are maintenance-free with a life expectancy of 15 years. The sealed rechargeable nickel cadmium battery offers high discharge rates and stable performance over a wide range of temperatures. The specially designed resealable vent automatically controls cell pressure, assuring safety and reliability. This battery is best suited for harsh ambient temperatures because the electrolyte is not active in the electrochemical process.

Warranty

All Sure-Lites' products are backed by a firm one-year warranty against defects in material and workmanship. Maintenance-free, long-life, sealed nickel cadmium batteries carry a fifteen-year pro-rated warranty.



Occupancy Sensors

| | |
|-------------|------|
| Catalog # | Type |
| Project | |
| Comments | |
| Prepared by | Date |

VAC-DT, MicroSet Dual Tech Vacancy Ceiling Sensor Low Voltage



PIR
Activated



Ultrasonic
Activated



MICROSET
Self-Adjusting



California
Title 24
Compliant

- MicroSet self-adjusting Time Delay and sensitivity
- Optional built-in light level sensor
- Optional BAS/HVAC isolated relay
- Products tested to NEMA WD 7 - 2011 Occupancy Motion Sensors Standard
- Requires Manual ON for activation

Specifications:

Technology: Passive Infrared (PIR) and Ultrasonic (US)
Power Requirements:

Input:

- 10-30 VDC from Greengate Switchpack or Greengate system.
- Maximum current needed is 25mA per sensor.

Output:

- Open collector output to switch up to ten Greengate Switchpacks.
- BAS with Isolated Form C Relay in (-R) model.
- Isolated Form C Relay Ratings: 1A 30 VDC/VAC.

Time Delays: Self-adjustable, 15 seconds/test (10 min. Auto), or Selectable 5, 15, 30 minutes, or Zero Time Delay

Coverage: 500, 1000, and 2000 sq. ft.

Light Level Sensing (-R models): 0 to 300 foot-candles

Operating Environment:

- Temperature: 32°F to 104°F (0°C to 40°C)
- Relative humidity: 20% to 90%, non-condensing
- For indoor use only

Housing: Durable, injection molded housing.

Polycarbonate resin complies with UL 94V0.

Size: 4.5"H x 1.42"W (114.3mm x 36.068mm)

LED lamp: Green LED for Ultrasonic


Red LED for Passive Infrared

Warranty: Five year

FCC Compliant

cULus Listed

RoHS Compliant



Overview

The Dual Technology sensor's combination of Ultrasonic and Passive Infrared technologies offers the most complete sensing equipment available today. This pairing helps eliminate false deactivations for additional energy savings. The VAC-DT sensors are also equipped with MicroSet self-adjusting technology which provides an adaptive and airflow tolerant technology, making them ideal for spaces which have increased airflow due to higher occupant levels. MicroSet self-adjusting Dual Technology sensors drastically simplify and reduce a contractor's installation and adjustment time period.

Technology

The MicroSet self-adjusting technology continuously monitors multiple sub-frequencies in the event that if a continuous Doppler shift occurs, such as those created by airflow from an air duct, the sensor will identify the noise as continuous and then block it out of view at a select sub-frequency. It will continue to monitor other sub-frequencies for human motion. This avoids false activation, while still maintaining the high level of sensitivity that is necessary for sensing minor motion in a changing environment. Separate concurrent time delays for both Passive Infrared and Ultrasonic technologies avoid false activations or deactivations. The lights are turned ON by activating a momentary switch (model # GMDS-*) that is connected to the sensor. When enabled, the daylighting feature (-R models only) prevents lights from turning ON when the room is adequately illuminated by natural light.

Applications

| | | |
|------------------|----------------|----------------------------|
| classrooms | common areas | other indoor office spaces |
| conference rooms | computer rooms | |
| office spaces | break rooms | |


Ordering

| Catalog # | Recommended Room Size | Field of View | Frequency | Features |
|---------------|-----------------------|----------------|-----------|-------------------------------|
| VAC-DT-2000-R | 2,000 sq.ft. | Two Way (360°) | 32 kHz | w/BAS Relay & Daylight Sensor |
| VAC-DT-1000-R | 1,000 sq.ft. | Two Way (360°) | 32 kHz | w/BAS Relay & Daylight Sensor |
| VAC-DT-0501-R | 500 sq.ft. | One Way (180°) | 40 kHz | w/BAS Relay & Daylight Sensor |


VAC-DT, MicroSet Dual Tech Low Voltage

Wiring Diagrams

One Sensor, One Switchpack




Manual On Control of Two Standard Switchpacks



Coverage


VAC-DT-0501-R

500 sq. ft.





VAC-DT-1000-R

1,000 sq. ft.



VAC-DT-2000-R

2,000 sq. ft.




Controls

DIP Switch Legend

| DIP Switch | Time Delay | | Not Used | | PIR Sensitivity | Not Used | | LEDs | Override | Sweep | Full/Half Logic | HVAC/Tracking | Zero Time Delay |
|------------|------------|---|----------|---|-----------------|----------|---------|---------|----------|-------|-----------------|---------------|-----------------|
| | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | |
| Auto* | ▼ | ▼ | | | Full | | Enable | Disable | Disable | Full | Disable | Disable | |
| 5 Minutes | ▼ | ▲ | | | 50% | | Disable | Enable | Enable | Half | Enable | Enable | |
| 15 Minutes | ▲ | ▼ | | | | | | | | | | | |
| 30 Minutes | ▲ | ▲ | | | | | | | | | | | |

*Self-Adjusts to 10 min. user mode

Default =



30HX Evergreen®

High-Efficiency
Indoor Liquid Screw Chillers

70 to 265 Nominal Tons

30HXA - Condenserless

30HXC - Water-cooled



[Back to Product Description](#)

30HXC 60 Hz Water-Cooled

| Size | Capacity (Tons) | IPLV (kW/Ton) | Dimensions (ft) | | | Operating Weight (lbs) |
|------|-----------------|---------------|-----------------|-------|--------|------------------------|
| | | | Length | Width | Height | |
| 076 | 74 | .53 | 8.5 | 2.8 | 5.4 | 5700 |
| 088 | 82 | .54 | 8.5 | 2.8 | 5.4 | 5723 |
| 096 | 92 | .53 | 8.5 | 2.8 | 5.4 | 5855 |
| 106 | 103 | .55 | 8.5 | 2.8 | 5.6 | 6177 |
| 116 | 112 | .53 | 8.5 | 2.8 | 5.4 | 6415 |
| 126 | 121 | .53 | 11.1 | 2.8 | 5.4 | 6465 |
| 136 | 134 | .56 | 11.1 | 2.8 | 5.4 | 6608 |
| 146 | 143 | .55 | 11.1 | 2.8 | 5.4 | 6718 |
| 161 | 166 | .58 | 11.1 | 2.9 | 5.8 | 7452 |
| 171 | 164 | .56 | 11.1 | 2.9 | 5.8 | 7660 |
| 186 | 176 | .59 | 11.1 | 2.9 | 5.8 | 7854 |
| 206 | 211 | .53 | 11.1 | 3 | 6.2 | 10581 |
| 246 | 246 | .54 | 12.4 | 3 | 6.2 | 10696 |
| 251 | 255 | .54 | 12.4 | 3 | 6.2 | 10992 |
| 271 | 265 | .54 | 12.4 | 3 | 6.2 | 11029 |

Contact your local Carrier representative for condenserless ratings.